

FAILED INSPECTION NOTICE

Property:

Fong Fong Ga

860 8TH ST

568 47Th Ave

RICHMOND, CA 94801-2225-

PropID:

Client ID: 16680

Dear Owner/Agent,

This letter is to inform you that your property at **860 8TH ST RICHMOND**, CA **94801-2225 failed** the Housing Quality Standards (HQS) inspection on 05/21/2024.

A re-inspection has been scheduled for 06/27/2024 between 01:00PM and 04:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
7.4	Heating and Plumbing/Water Heater	O
	install proper hot water heater straps upper and lower	
8.4	General Health and Safety/Garbage and Debris	O
	remove excessive trash and debris from back yard	
8.10	General Health and Safety/Site and Neighborhood Conditions	O
	cut overgrown vegetation	
2.12	Kitchen/Sink	O
	faucet leaking,repair	
2.10	Kitchen/Stove or Range with Oven	O
	all burners must self-ignite	
7.1	Heating and Plumbing/Adequacy of Heating Equipment	O
	heater inoperable	
3.12	Bathroom/Tub or Shower	O
	faucet handle pulling off,repair	
3.5	Bathroom/Window Condition	O
	window cracked,repair	
4.4	Other Rooms/Security	O
	no accesss, must provide access at next inspection	
8.6	General Health and Safety/Interior Stairs and Common Halls	O
	install transition strips to bedrooms and bathrooms	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Wai Si Chong 5723 Agnes Ave Temple City, CA 91780

Property:
545 19TH ST
RICHMOND, CA 94801-2817-

PropID:

Client ID: 8533

Dear Owner/Agent,

This letter is to inform you that your property at **545 19TH ST RICHMOND**, CA **94801-2817 failed** the Housing Quality Standards (HQS) inspection on 05/21/2024.

A re-inspection has been scheduled for 06/27/2024 between 01:00PM and 04:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner_
2.10	Kitchen/Stove or Range with Oven	0
	right rear burner knobs broken	
8.7	General Health and Safety/Other Interior Hazards	O
	install common area smoke detectors and co detectors up and downstairs.	
4.10	Other Rooms/Smoke Detectors	O
	Smoke detector is missing. All units must have at least one operable smoke	
	detector in each bedroom and in a common area on each level. all	
	bedrooms in unit	
3.12	Bathroom/Tub or Shower	O
	upstairs bathroom faucet loose	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Kenneth R & Felicia Lind 6790 Sunriver Ln Vallejo, CA 94591-6312 Property: 334 1ST ST Apt A RICHMOND, CA 94801-2901-

PropID:

Client ID: 8129

Dear Owner/Agent,

This letter is to inform you that your property at **334 1ST ST Apt A RICHMOND**, **CA 94801-2901 failed** the Housing Quality Standards (HQS) inspection on 05/21/2024.

A re-inspection has been scheduled for 06/27/2024 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS 3.12 Bathroom/Tub or Shower tub rusting, resurface tub and recaulk around tub

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Nathan & Christine Belete 861 Aileen St Oakland, CA 94608 Property: 408 19TH ST RICHMOND, CA 94801-3223-

PropID:

Client ID: 17852

Dear Owner/Agent,

This letter is to inform you that your property at **408 19TH ST RICHMOND**, CA **94801-3223 failed** the Housing Quality Standards (HQS) inspection on 05/21/2024.

A re-inspection has been scheduled for 06/27/2024 between 01:00PM and 04:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
3.3	Bathroom/Electrical Hazards	O
	install Gfi outlet	
3.7	Bathroom/Wall Condition	O
	wall paint cracking, repair	
3.6	Bathroom/Ceiling Condition	O
	ceiling paint cracking, repair	
2.7	Kitchen/Wall Condition	T
	clean excessive grease spatter on walls	
2.3	Kitchen/Electrical Hazards	О
	install Gfi outlets	
2.13	Kitchen/Space for Storage, Prep and Serving	О
	1. bottom of cabinet under sink evidence of water damage,repair	
	2. cabinet drawer fronts missing,install	
2.10	Kitchen/Stove or Range with Oven	0
	venthood fan and light inoperabl,repair	Ü
1.3	Living Room/Electrical Hazards	O
	Three prong outlet not testing as designed, must be grounded, replaced with	
	a two-prong outlet or replaced with a GFCI.	
6.4	Building Exterior/Condition of Exterior Surfaces	О
	garage door paint excessive peeling,repair	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Juli Silva Professional Property Management 223 Almond Ridge Ct El Dorado Hills, CA 95762-9555 Property: 2515 GARVIN AVE RICHMOND, CA 94804-1376-

PropID:

Client ID: 8478

Dear Owner/Agent,

This letter is to inform you that your property at **2515 GARVIN AVE RICHMOND, CA 94804-1376 failed** the Housing Quality Standards (HQS) inspection on 05/21/2024.

A re-inspection has been scheduled for 07/01/2024 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS Tenant/Owner

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Ba Van Luong 1072 Victoria Park Hercules, CA 94804 Property: 3716 WALLER AVE Apt LOWER RICHMOND, CA 94804-3329-

PropID:

Client ID: 17236

Dear Owner/Agent,

This letter is to inform you that your property at **3716 WALLER AVE Apt LOWER RICHMOND, CA 94804-3329 failed** the Housing Quality Standards (HQS) inspection on 05/21/2024.

A re-inspection has been scheduled for 07/01/2024 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS 8.4 General Health and Safety/Garbage and Debris clean front of unit .excessive trash

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Ba Van Luong 1072 Victoria Park Hercules, CA 94804 Property: 3716 WALLER AVE Apt UPPER RICHMOND, CA 94804-3329-

PropID:

Client ID: 17236

Dear Owner/Agent,

This letter is to inform you that your property at 3716 WALLER AVE Apt UPPER RICHMOND, CA 94804-3329 failed the Housing Quality Standards (HQS) inspection on 05/21/2024.

A re-inspection has been scheduled for 07/01/2024 between 11:00AM and 02:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
2.13	Kitchen/Space for Storage, Prep and Serving	O
	lazy suzy cabinet door off	
2.11	Kitchen/Refrigerator	O
	door handle loose/not attached as designed,repair	
3.12	Bathroom/Tub or Shower	O
	tub surface peeling/deteriorating ,resurface/repair tub	
8.7	General Health and Safety/Other Interior Hazards	O
	install common area co/smoke detectors	
4.10	Other Rooms/Smoke Detectors	O
	Smoke detector is missing/inoperable. All units must have at least one	
	operable smoke detector in each bedroom and in a common area on each	
	level.	
7.1	Heating and Plumbing/Adequacy of Heating Equipment	O
	front bedroom heater inoperable	
2.10	Kitchen/Stove or Range with Oven	O
	microwave inoperable,repair/replace	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Peng Xu 29 Via Barcelona Moraga, CA 94556 Property: 886 CARLSON BLVD RICHMOND, CA 94804-4643-

PropID:

Client ID: 13593

Dear Owner/Agent,

This letter is to inform you that your property at **886 CARLSON BLVD RICHMOND, CA 94804-4643 failed** the Housing Quality Standards (HQS) inspection on 05/21/2024.

A re-inspection has been scheduled for 07/01/2024 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS Tenant/Owner

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,