



6/2/2026

**FAILED INSPECTION NOTICE**

2410 ABERDEEN WAY Apt 13  
RICHMOND, CA 94806-2590-

PropID:  
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2410 ABERDEEN WAY Apt 13 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 05/27/2026.

**A re-inspection has been scheduled for 07/17/2026 between 09:00AM and 12:00PM.**

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
2.12 Kitchen/Sink	5/27/2026 Dishwasher drains through air gap, repair as drain must go through garbage disposal.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond  
Residential Rental Inspections Program



6/2/2026

**FAILED INSPECTION NOTICE**

2412 ABERDEEN WAY Apt 1  
RICHMOND, CA 94806-2590-

PropID:  
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2412 ABERDEEN WAY Apt 1 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 05/27/2026.

**A re-inspection has been scheduled for 07/17/2026 between 11:00AM and 02:00PM.**

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
4.4	Other Rooms/Security Remove keyed lock from interior door.
4.5	Other Rooms/Window Condition Window must be openable and remain open without props. - Right window will not stay open as designed, repair - Lower fixed window rusted, repair or replace
2.12	Kitchen/Sink Dishwasher drains through air gap onto counter. Repair as drain must go through garbage disposal.
2.5	Kitchen/Window Condition Lower fixed window rusted, repair or replace
3.12	Bathroom/Tub or Shower Shower head leaking in rear, repair



6/2/2026

**FAILED INSPECTION NOTICE**

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond  
Residential Rental Inspections Program