



6/2/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 1
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 1 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 05/29/2026.

A re-inspection has been scheduled for 07/17/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
4.5	Other Rooms/Window Condition Move furniture blocking access to window (fire exit)
3.13	Bathroom/Ventilation Vent fan inoperable, repair or remove
2.12	Kitchen/Sink Dishwasher drains through air gap, repair as drain must go through garbage disposal.
8.2	General Health and Safety/Exits Clear items blocking access to patio door (fire exit)



6/2/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/2/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 10
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 10 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 05/29/2026.

A re-inspection has been scheduled for 07/17/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
4.10	Other Rooms/Smoke Detectors Smoke detector is inoperable or missing. All units must have at least one operable smoke detector on each level. The smoke detector must be placed according to package instructions.
4.5	Other Rooms/Window Condition Window must be openable and remain open without props.
2.12	Kitchen/Sink Dishwasher drains through air gap, repair as drain must go through garbage disposal.



6/2/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/2/2026

FAILED INSPECTION NOTICE

2410 LANCASTER DR Apt 3
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2410 LANCASTER DR Apt 3 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 05/29/2026.

A re-inspection has been scheduled for 07/17/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
8.6	General Health and Safety/Interior Stairs and Common Halls Install common area smoke detector in unit
2.12	Kitchen/Sink Kitchen faucet has constant drip, repair
2.11	Kitchen/Refrigerator Refrigerator/Freezer does not maintain temperature.
8.2	General Health and Safety/Exits Clear path to patio door (fire exit)



6/2/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/2/2026

FAILED INSPECTION NOTICE

2410 LANCASTER DR Apt 9
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2410 LANCASTER DR Apt 9 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 05/29/2026.

A re-inspection has been scheduled for 07/17/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
4.10	Other Rooms/Smoke Detectors Replace, exceeds 10 year life span
2.12	Kitchen/Sink Dishwasher drains through air gap, repair as drain must go through garbage disposal.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program