



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 1528
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 1528 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/27/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
7.4	Heating and Plumbing/Water Heater remove clutter from water heater closet.	O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 1533
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 1533 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/27/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
2.12	Kitchen/Sink unclogged sink.	O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 1716
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 1716 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/27/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
1.4	Living Room/Security broken door handle. repair or replace.	O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 1721
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 1721 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/27/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
1.8	Living Room/Floor Condition torn carpet exposed nails trip hazard. repair or replace.	O
3.11	Bathroom/Fixed Wash Basin or Lavatory in Unit chipping and peeling inside of sink. resurface or replace.	O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 1723
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 1723 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/27/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
3.10	Bathroom/Flush Toilet in Enclosed Room in Unit flushing mechanism not working like designed repair or replace.	O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 1725
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 1725 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/27/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
3.10	Bathroom/Flush Toilet in Enclosed Room in Unit toilet not flushing like designed. repair or replace.	O
3.7	Bathroom/Wall Condition broken toilet paper holder. repair or replace	O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 1727
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 1727 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/27/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
2.3	Kitchen/Electrical Hazards GFCI outlet will not trip and reset as designed. repair or replace.	O
1.8	Living Room/Floor Condition torn carpet exposed nails near front entrance. repair	O
3.11	Bathroom/Fixed Wash Basin or Lavatory in Unit chipping inside sink. resurface or replace.	O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 628
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 628 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
4.10	Other Rooms/Smoke Detectors Smoke detector has low audible alert, replace	O
2.10	Kitchen/Stove or Range with Oven Right rear burner inoperable, repair	O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 631
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 631 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
4.4	Other Rooms/Security REFUSAL OF ENTRY INTO BEDROOM 2, OCCUPIED. TENANT MUST PROVIDE ACCESS TO ROOM FOR INSPECTION	T
3.1	Bathroom/Bathroom Present NO ACCESS TO BATHROOM 2 IN RIGHT BEDROOM, TENANT MUST PROVIDE ACCESS TO BATHROOM	T
2.11	Kitchen/Refrigerator Door gasket damaged, repair Light inoperable, repair	O



6/17/2025

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 633
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 633 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
4.10	Other Rooms/Smoke Detectors Bedroom smoke detector missing, replace	T

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 635
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 635 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
7.5	Heating and Plumbing/Water Supply Water heater pilot light cover missing, replace	O
2.10	Kitchen/Stove or Range with Oven Rear burners not self lighting, repair	O
4.8	Other Rooms/Floor Condition Carpet torn at entry, repair	O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 637
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 637 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
7.4	Heating and Plumbing/Water Heater Tenant to move personal items stored in hot water heater closet	T

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 638
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 638 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
8.4	General Health and Safety/Garbage and Debris Remove excessive recycling from patio	T

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 711
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 711 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
4.5	Other Rooms/Window Condition Tenant to move bed blocking access to window (fire exit)	T
2.12	Kitchen/Sink Dishwasher inoperable, repair	O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 712
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 712 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
2.12	Kitchen/Sink Dishwasher inoperable, repair	O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 713
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 713 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
3.12	Bathroom/Tub or Shower Clean discoloration in tub	T
8.6	General Health and Safety/Interior Stairs and Common Halls Common area smoke detector/carbon monoxide detector inoperable, repair or replace	O
2.10	Kitchen/Stove or Range with Oven Range hood light inoperable, repair	O
2.12	Kitchen/Sink Garbage disposal inoperable, repair	O
8.3	General Health and Safety/Evidence of Infestation Tenant to clean and remove dead knats in refrigerator/freezer	T



6/17/2025

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 714
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 714 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
8.6	General Health and Safety/Interior Stairs and Common Halls Common area smoke detector/carbon monoxide detector on left side inoperable, replace	O
3.7	Bathroom/Wall Condition Clean discoloration on walls	O
7.4	Heating and Plumbing/Water Heater Remove excessive clutter in hot water heater closet	O
4.10	Other Rooms/Smoke Detectors Smoke detector is inoperable or missing. All units must have at least one operable smoke detector on each level. The smoke detector must be placed according to package instructions.	O
2.10	Kitchen/Stove or Range with Oven Range hood light inoperable, repair	O



6/17/2025

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 715
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 715 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
3.12	Bathroom/Tub or Shower Shower head leaking in left bathroom, repair	O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 716
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 716 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
8.4	General Health and Safety/Garbage and Debris Declutter unit, excessive trash in unit	T
8.1	General Health and Safety/Access to Unit Patio screen off track, repair	O
4.5	Other Rooms/Window Condition Clean discoloration in window	T
3.12	Bathroom/Tub or Shower Shower head leaking, repair	O
2.12	Kitchen/Sink Garbage disposal inoperable, repair	O
2.11	Kitchen/Refrigerator Refrigerator/Freezer does not maintain temperature.	O

Refrigerator has evidence of it leaking in front of unit, repair



6/17/2025

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 717
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 717 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
7.4	Heating and Plumbing/Water Heater Tenant to move personal items stored in hot water heater closet	T

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 724
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 724 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
3.12	Bathroom/Tub or Shower Peeling paint inside of left bathroom tub, repair	O
3.11	Bathroom/Fixed Wash Basin or Lavatory in Unit The wash basin is clogged.	O
7.4	Heating and Plumbing/Water Heater NO access to hot water heater, tenant to move items blocking hot water heater closet	T



6/17/2025

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 726
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 726 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
3.3	Bathroom/Electrical Hazards Bathroom ceiling light inoperable, repair	O
2.10	Kitchen/Stove or Range with Oven Right rear burner not self lighting, repair	O
2.11	Kitchen/Refrigerator Light inoperable, repair	O
2.12	Kitchen/Sink Dishwasher inoperable, repair	O
7.4	Heating and Plumbing/Water Heater Tenant to move personal items stored in hot water heater closet	T



6/17/2025

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 727
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 727 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
8.6	General Health and Safety/Interior Stairs and Common Halls Common area smoke detector/ carbon monoxide detector removed, replace	T
7.4	Heating and Plumbing/Water Heater Tenant to move personal items stored in hot water heater closet	T

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



6/17/2025

FAILED INSPECTION NOTICE

Richmond Essex Lp
TRENNILLE A BRASS
2601 Hilltop Drive, Leasing Office
Richmond, CA 94806

Property:
2601 HILLTOP DR Apt 731
RICHMOND, CA 94806-5783-

PropID:
Client ID: 7274

Dear Owner/Agent,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 731 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 06/10/2025.

A re-inspection has been scheduled for 08/25/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>	<u>Tenant/Owner</u>
2.10	Kitchen/Stove or Range with Oven Unable to test burners as tenant removed knobs, reinstall knobs for inspection	T
2.11	Kitchen/Refrigerator Light inoperable, repair	O
3.10	Bathroom/Flush Toilet in Enclosed Room in Unit Tenant to clean heavy discoloration in toilet	T
4.5	Other Rooms/Window Condition Window screen torn, repair	O
4.8	Other Rooms/Floor Condition Carpet torn at entry, repair	O
8.4	General Health and Safety/Garbage and Debris Tenant to remove excessive items stored on patio	T
7.4	Heating and Plumbing/Water Heater Tenant to clear excessive amount of items on patio to allow access to hot water heater closet	T
2.12	Kitchen/Sink Garbage disposal inoperable, repair	O



6/17/2025

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program