

FAILED INSPECTION NOTICE

1201 BRICKYARD Apt #206	PropID:
RICHMOND, CA 94801-4141-	Client ID: 2178

Dear Current Resident,

This letter is to inform you that your property at **1201 BRICKYARD Apt #206 RICHMOND, CA 94801-4141 failed** the Housing Quality Standards (HQS) inspection on 06/23/2025.

A re-inspection has been scheduled for 08/27/2025 between 01:00PM and 04:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
8.8	General Health and Safety/Elevators	O
	The elevator certificate is missing or expired; this represents a SAFETY	
	HAZARD which must be corrected.	
3.12	Bathroom/Tub or Shower	O
	Shower head leaking, repair	
	Install safety guides for glass shower doors	
3.3	Bathroom/Electrical Hazards	O
	Outlet has hot/nuetral reverse, repair	
4.3	Other Rooms/Elecrtical Hazards	O
	Damaged outlet presents an electrical hazard. Replace cracked receptacles	
	on left and right side of window	
1.3	Living Room/Electrical Hazards	O
	Damaged outlet presents an electrical hazard. Replace multiple cracked	
	receptacles in living room and sun room	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

1201 BRICKYARD WAY Apt #407	PropID:	
RICHMOND, CA 94801-4143-	Client ID:	3596

Dear Current Resident,

This letter is to inform you that your property at **1201 BRICKYARD WAY Apt #407 RICHMOND, CA 94801-4143 failed** the Housing Quality Standards (HQS) inspection on 06/23/2025.

A re-inspection has been scheduled for 08/27/2025 between 01:00PM and 04:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
8.8	General Health and Safety/Elevators	O
	The elevator certificate is missing or expired; this represents a SAFETY	
	HAZARD which must be corrected.	
1.3	Living Room/Electrical Hazards	O
	Ceiling light inoperable, repair	
2.3	Kitchen/Electrical Hazards	О
	Kitchen light inoperable, repair	
1.5	Living Room/Window Condition	O
	Units will be required to have screens on one exterior window per room, if	
	the window is openable. The screens must be removable for egress in case	
	of an emergency.	
4.10	Other Rooms/Smoke Detectors	O
	Smoke detector is inoperable or missing. All units must have at least one	
	operable smoke detector on each level. The smoke detector must be	
	placed according to package insturctions.	
4.3	Other Rooms/Elecrtical Hazards	O
	Replace cracked receptacle left of bedroom window	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2937 DE ANZA DR PropID: RICHMOND, CA 94803-2401- Client ID: 1761

Dear Current Resident,

This letter is to inform you that your property at **2937 DE ANZA DR RICHMOND, CA 94803-2401 failed** the Housing Quality Standards (HQS) inspection on 06/23/2025.

A re-inspection has been scheduled for 08/27/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
4.5	Other Rooms/Window Condition	T
	Tenant to move large dresser/mirror preventing direct access to window.	
	Unable to access, tenant to provide access and clear items blocking sole	
	fire exit in bedroom.	
8.1	General Health and Safety/Access to Unit	O
	Install door sweep on rear door in garage to prevent light/air intrusion.	

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

5616 SACRAMENTO AVE	PropID:
RICHMOND, CA 94804-	Client ID: 13247

Dear Current Resident,

This letter is to inform you that your property at **5616 SACRAMENTO AVE RICHMOND, CA 94804 failed** the Housing Quality Standards (HQS) inspection on 06/23/2025.

A re-inspection has been scheduled for 08/29/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
5.4	Secondary Rooms/Other Potential Hazardous Features	O
	Window above laundry appliances missing screen, install	
4.4	Other Rooms/Security	O
	Remove keyed lock from interior door. Remove deadbolt lock from	
	bedroom door as well.	

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

248 23RD ST Apt 1 RICHMOND, CA 94804-

Client ID: 14973

PropID:

Dear Current Resident,

This letter is to inform you that your property at **248 23RD ST Apt 1 RICHMOND**, CA **94804 failed** the Housing Quality Standards (HQS) inspection on 06/23/2025.

A re-inspection has been scheduled for 08/29/2025 between 11:00AM and 02:00PM.



FAILED INSPECTION NOTICE

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
8.6	General Health and Safety/Interior Stairs and Common Halls	O
	Install common area some detector in unit	
7.1	Heating and Plumbing/Adequacy of Heating Equipment	O
	Heaters in living room and front room inoperable, repair	
8.7	General Health and Safety/Other Interior Hazards	O
	Smoke detector in kitchen missing, base present. Remove as unit needs one	
	common area smoke detector or replace	
4.10	Other Rooms/Smoke Detectors	O
	Smoke detector is inoperable or missing. All units must have at least one	
	operable smoke detector on each level. The smoke detector must be	
	placed according to package insturctions.	
4.5	Other Rooms/Window Condition	O
	Units will be required to have screens on one exterior window per room, if	
	the window is openable. The screens must be removable for egress in case	
	of an emergency.	
2.11	Kitchen/Refrigerator	O
	Light inoperable, repair	
2.3	Kitchen/Electrical Hazards	O
	Replace missing cover plates on 2 outlets in kitchen, one left side of	
	counter, 2nd is on wall across from countertop	
8.3	General Health and Safety/Evidence of Infestation	O
	Exterminate for roaches.	
1.5	Living Room/Window Condition	O
	Units will be required to have screens on one exterior window per room, if	
	the window is openable. The screens must be removable for egress in case	
	of an emergency.	
2.6	Kitchen/Ceiling Condition	T
	Clean discoloration on ceiling and kitchen vent fan, excessive grease	
	splatter	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

248 23RD ST Apt 2	PropID:
RICHMONC, CA 94804-	Client ID: 14973

Dear Current Resident,

This letter is to inform you that your property at **248 23RD ST Apt 2 RICHMONC**, CA **94804 failed** the Housing Quality Standards (HQS) inspection on 06/23/2025.

A re-inspection has been scheduled for 08/29/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
8.3	General Health and Safety/Evidence of Infestation	O
	Exterminate for roaches. Heavy infestation throughout unit	
3.12	Bathroom/Tub or Shower	O
	Install safety guides for shower doors	
4.4	Other Rooms/Security	T
	Remove keyed lock from interior door.	
4.10	Other Rooms/Smoke Detectors	T
	Smoke detector is inoperable or missing. All units must have at least one	
	operable smoke detector on each level. The smoke detector must be	
	placed according to package insturctions.	
8.6	General Health and Safety/Interior Stairs and Common Halls	O
	Install common area smoke detector in unit	

Install carbon monoxide detector in unit, gas appliances present



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

712 S 45TH ST RICHMOND, CA 94804PropID:

Client ID: 19520

Dear Current Resident,

This letter is to inform you that your property at **712 S 45TH ST RICHMOND**, **CA 94804 failed** the Housing Quality Standards (HQS) inspection on 06/23/2025.

A re-inspection has been scheduled for 08/29/2025 between 09:00AM and 12:00PM.



FAILED INSPECTION NOTICE

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
1.3	Living Room/Electrical Hazards	O
	Three prong outlet not testing as designed, must be grounded, replaced with	
	a two-prong outlet or replaced with a GFCI.	
8.1	General Health and Safety/Access to Unit	O
	Portion of address on front of unit missing. replace	
8.6	General Health and Safety/Interior Stairs and Common Halls	O
	Common area smoke detector inoperable, repair or replace	
8.10	General Health and Safety/Site and Neighborhood Conditions	O
	Cut down brush in front of unit that is covering portion of sidewalk.	
4.3	Other Rooms/Elecrtical Hazards	O
	Three prong outlet not testing as designed, must be grounded or replaced	
	with a GFCI.	
4.10	Other Rooms/Smoke Detectors	O
	Smoke detector is inoperable or missing. All units must have at least one	
	operable smoke detector on each level. The smoke detector must be	
	placed according to package insturctions.	
3.12	Bathroom/Tub or Shower	O
	The tub, shower is clogged.	
7.1	Heating and Plumbing/Adequacy of Heating Equipment	O
	Heater inoperable, repair. Digital thermostat has no display	
2.3	Kitchen/Electrical Hazards	O
	Three prong outlet not testing as designed, must be grounded, replaced with	
	a two-prong outlet or replaced with a GFCI.	
4.4	Other Rooms/Security	T
	Remove keyed lock from interior door.	
6.4	Building Exterior/Condition of Exterior Surfaces	O
	Outlet in rear of unit next to hot water heater missing weatherproof cover,	
	install.	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

746 S 49TH ST	PropID:
RICHMOND, CA 94804-4427-	Client ID: 8511

Dear Current Resident,

This letter is to inform you that your property at **746 S 49TH ST RICHMOND**, **CA 94804-4427 failed** the Housing Quality Standards (HQS) inspection on 06/23/2025.

A re-inspection has been scheduled for 08/29/2025 between 09:00AM and 12:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
4.10	Other Rooms/Smoke Detectors	O
	Smoke detector is inoperable or missing. All units must have at least one	
	operable smoke detector on each level. The smoke detector must be	
	placed according to package insturctions.	
4.3	Other Rooms/Elecrtical Hazards	O
	Outlets have open grounds, repair	
2.10	Kitchen/Stove or Range with Oven	O
	Range hood light inoperable, repair	
1.3	Living Room/Electrical Hazards	O
	Outlets have open grounds, repair	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

3320 ESMOND AVE RICHMOND, CA 94805-1323PropID:

Client ID: 8500

Dear Current Resident,

This letter is to inform you that your property at **3320 ESMOND AVE RICHMOND**, **CA 94805-1323 failed** the Housing Quality Standards (HQS) inspection on 06/23/2025.

A re-inspection has been scheduled for 08/26/2025 between 11:00AM and 02:00PM.



FAILED INSPECTION NOTICE

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
1.4	Living Room/Security	T
	Remove latch style add on lock from front door	
2.10	Kitchen/Stove or Range with Oven	T
	Range hood vent screen missing, replace/install	
2.12	Kitchen/Sink	O
	Garbage disposal inoperable, repair	
5.4	Secondary Rooms/Other Potential Hazardous Features	O
	Install window screen in laundry area	
4.3	Other Rooms/Elecrtical Hazards	T
	Light switch cover missing, replace	
4.10	Other Rooms/Smoke Detectors	O
	Smoke detector is missing. All units must have at least one operable smoke	
	detector in each bedroom and in a common area on each level.	
4.5	Other Rooms/Window Condition	O
	Units will be required to have screens on one exterior window per room, if	
	the window is openable. The screens must be removable for egress in case	
	of an emergency.	
4.4	Other Rooms/Security	T
	Remove keyed lock from interior door.	
6.4	Building Exterior/Condition of Exterior Surfaces	O
	Rear exterior outlet missing weatherproof cover, install	
8.4	General Health and Safety/Garbage and Debris	T
	Remove excessive recycling from yard	

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

327 36TH ST	PropID:
RICHMOND, CA 94805-2125-	Client ID: 19527

Dear Current Resident,

This letter is to inform you that your property at **327 36TH ST RICHMOND**, **CA 94805-2125 failed** the Housing Quality Standards (HQS) inspection on 06/23/2025.

A re-inspection has been scheduled for 08/26/2025 between 01:00PM and 04:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
8.1	General Health and Safety/Access to Unit	O
	Install turnstyle knob on front screen door	
	Install door sweep on rear door to prevent air/light intrusion	
8.6	General Health and Safety/Interior Stairs and Common Halls	O
	Common area smoke detector level 2 inoperable, repair or replace	
4.3	Other Rooms/Elecrtical Hazards	T
	No access to outlets for inspection, tenant to clear items in room to allow	
	access for inspection	
7.1	Heating and Plumbing/Adequacy of Heating Equipment	O
	Heater inoperable, repair	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

329 36TH ST	PropID:
RICHMOND, CA 94805-2125-	Client ID: 19527

Dear Current Resident,

This letter is to inform you that your property at **329 36TH ST RICHMOND**, CA **94805-2125 failed** the Housing Quality Standards (HQS) inspection on 06/23/2025.

A re-inspection has been scheduled for 08/26/2025 between 01:00PM and 04:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
8.7	General Health and Safety/Other Interior Hazards	0
	Hall light level 2 inoperable, repair	Ü
3.10	Bathroom/Flush Toilet in Enclosed Room in Unit	O
	Bath Toilet not secured properly to floor.	
3.12	Bathroom/Tub or Shower	O
	Shower head leaking, repair	
2.3	Kitchen/Electrical Hazards	0
	Right light inoperable, repair	
7.1	Heating and Plumbing/Adequacy of Heating Equipment	O
	Heater inoperable, repair	
8.1	General Health and Safety/Access to Unit	O
	Install deadbolt on rear door that leads to exterior of complex	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

331 36TH ST	PropID:
RICHMOND, CA 94805-2125-	Client ID: 19527

Dear Current Resident,

This letter is to inform you that your property at 331 36TH ST RICHMOND, CA 94805-2125 failed the Housing Quality Standards (HQS) inspection on 06/23/2025.

A re-inspection has been scheduled for 08/26/2025 between 01:00PM and 04:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
8.1	General Health and Safety/Access to Unit	O
	Install turnstile knob on screen door, missing	
3.12	Bathroom/Tub or Shower	O
	Tub diverter inoperable as tub runs at same time as shower, repair	
3.5	Bathroom/Window Condition	O
	1- Window wont close as designed, repair	
	2- Install window screen	
4.10	Other Rooms/Smoke Detectors	T
	Smoke detector is inoperable or missing. All units must have at least one	
	operable smoke detector on each level. The smoke detector must be	
	placed according to package insturctions.	
4.4	Other Rooms/Security	T
	Remove keyed lock from interior door.	
5.4	Secondary Rooms/Other Potential Hazardous Features	T
	Smoke alarm in garage missing, replace	
2.10	Kitchen/Stove or Range with Oven	O
	Ventilation fan above stove inoperable, repair	
8.4	General Health and Safety/Garbage and Debris	O
	Remove clutter in rear yard	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,