

FAILED INSPECTION NOTICE

318 WASHINGTON AVE RICHMOND, CA 94801-3904PropID:

Client ID: 7024

Dear Current Resident,

This letter is to inform you that your property at **318 WASHINGTON AVE RICHMOND, CA 94801-3904 failed** the Housing Quality Standards (HQS) inspection on 07/18/2025.

A re-inspection has been scheduled for 09/16/2025 between 11:00AM and 02:00PM.



FAILED INSPECTION NOTICE

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
4.4	Other Rooms/Security	O
	Remove dead bolt locks from bedroom doors (front and rear) Remove	
	keyed lock from interior door.	
4.5	Other Rooms/Window Condition	O
	Units will be required to have screens on one exterior window per room, if	
	the window is openable. The screens must be removable for egress in case	
	of an emergency.	
3.5	Bathroom/Window Condition	O
	Units will be required to have screens on one exterior window per room, if	
	the window is openable. The screens must be removable for egress in case	
	of an emergency.	
5.4	Secondary Rooms/Other Potential Hazardous Features	O
	Install window screen in rear office room	
8.1	General Health and Safety/Access to Unit	O
	Remove deadbolt from door (interior) in laundry room and install window	
	screen in laundry room	
2.10	Kitchen/Stove or Range with Oven	O
	Right burners not self lighting, repair	
1.5	Living Room/Window Condition	O
	Units will be required to have screens on one exterior window per room, if	
	the window is openable. The screens must be removable for egress in case	
	of an emergency. DINING ROOM	

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

322 WASHINGTON AVE	PropID:	
RICHMOND, CA 94801-3904-	Client ID:	7024

Dear Current Resident,

This letter is to inform you that your property at **322 WASHINGTON AVE RICHMOND, CA 94801-3904 failed** the Housing Quality Standards (HQS) inspection on 07/18/2025.

A re-inspection has been scheduled for 09/16/2025 between 11:00AM and 02:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
3.5	Bathroom/Window Condition	O
	Units will be required to have screens on one exterior window per room, if	
	the window is openable. The screens must be removable for egress in case	
	of an emergency.	
2.5	Kitchen/Window Condition	O
	Units will be required to have screens on one exterior window per room, if	
	the window is openable. The screens must be removable for egress in case	
	of an emergency.	
5.4	Secondary Rooms/Other Potential Hazardous Features	O
	Repair peeling paint on ceiling in rear room	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

123 WOODSTOCK CT RICHMOND, CA 94803PropID:

Client ID: 16356

Dear Current Resident,

This letter is to inform you that your property at **123 WOODSTOCK CT RICHMOND, CA 94803 failed** the Housing Quality Standards (HQS) inspection on 07/18/2025.

A re-inspection has been scheduled for 09/16/2025 between 09:00AM and 12:00PM.



FAILED INSPECTION NOTICE

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
8.6	General Health and Safety/Interior Stairs and Common Halls	O
	1- 2nd level common area smoke detector removed. replace	
	2- 1st level smoke detector at front door missing, replace	
	3- Smoke detector outside of kitchen needs to be replaced, exceeds 10	
	year life span	
	4- Install/replace missing door knob on hall closet door	
4.10	Other Rooms/Smoke Detectors	O
	Smoke detector is inoperable or missing. All units must have at least one	O
	operable smoke detector on each level. The smoke detector must be	
	placed according to package insturctions. REPLACE, EXCEEDS 10	
	YEAR LIFE SPAN	
4.3	Other Rooms/Elecrtical Hazards	T
	A missing and/or cracked coverplate presents an electrical hazard. Outlet	_
	on right wall missing cover plate, install	
3.12	Bathroom/Tub or Shower	O
	Install safety guides for shower doors, level 1	
8.1	General Health and Safety/Access to Unit	O
	Garage door leading to exterior missing striker plates, replace/install	
1.5	Living Room/Window Condition	O
	Repair exterior window frame, dry rotted	
3.3	Bathroom/Electrical Hazards	O
	INSTALL GFCI outlets by sink	
3.8	Bathroom/Floor Condition	O
	The floor indicates a condition where the tenant is exposed to the danger of	
	structural collapse. Repair soft spot by toilet	
4.4	Other Rooms/Security	T
	Remove keyed entry lock from closet door	
3.11	Bathroom/Fixed Wash Basin or Lavatory in Unit	O
	Right sink faucet inoperable, repair	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

105 BIG BEAR CT	PropID:	
RICHMOND, CA 94803-2647-	Client ID:	1399

Dear Current Resident,

This letter is to inform you that your property at **105 BIG BEAR CT RICHMOND**, CA **94803-2647 failed** the Housing Quality Standards (HQS) inspection on 07/18/2025.

A re-inspection has been scheduled for 09/16/2025 between 11:00AM and 02:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
3.3	Bathroom/Electrical Hazards	O
	GFCI in master bedroom has hot/neutral reverse, repair	
4.10	Other Rooms/Smoke Detectors	O
	Smoke detector is inoperable or missing. All units must have at least one	
	operable smoke detector on each level. The smoke detector must be	
	placed according to package insturctions. REPLACE, EXCEEDS 10	
	YEAR LIFE SPAN	
8.1	General Health and Safety/Access to Unit	O
	Install door sweep on garage door leading to exterior	
3.5	Bathroom/Window Condition	O
	Units will be required to have screens on one exterior window per room, if	
	the window is openable. The screens must be removable for egress in case	
	of an emergency.	
	Bathroom located by laundry room	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

4071 MOZART DR	PropID:
RICHMOND, CA 94803-2749-	Client ID: 4470

Dear Current Resident,

This letter is to inform you that your property at **4071 MOZART DR RICHMOND**, CA **94803-2749 failed** the Housing Quality Standards (HQS) inspection on 07/18/2025.

A re-inspection has been scheduled for 09/16/2025 between 09:00AM and 12:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
3.3	Bathroom/Electrical Hazards	O
	Install GFCI outlet by sink.	
2.12	Kitchen/Sink	O
	Dishwasher drains through air gap, repair as drain must go through garbage	
	disposal.	
2.6	Kitchen/Ceiling Condition	O
	Remove old smoke detector base from ceiling	
1.3	Living Room/Electrical Hazards	O
	Damaged outlet presents an electrical hazard. Replace cracked receptacle	
	on left wall.	
8.7	General Health and Safety/Other Interior Hazards	O
	Install key blanks in openings in fuse panel located in garage	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

5488 BROOKWOOD LN	PropID:	
RICHMOND, CA 94803-3883-	Client ID:	1270

Dear Current Resident,

This letter is to inform you that your property at **5488 BROOKWOOD LN RICHMOND, CA 94803-3883 failed** the Housing Quality Standards (HQS) inspection on 07/18/2025.

A re-inspection has been scheduled for 09/16/2025 between 09:00AM and 12:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	<u>Tenant/Owner</u>
2.12	Kitchen/Sink	O
	Dishwasher drains through air gap, repair as it must drain through garbage	
	disposal.	
8.6	General Health and Safety/Interior Stairs and Common Halls	O
	Replace missing smoke detector level 2 common hallway	
8.7	General Health and Safety/Other Interior Hazards	O
	1st level smoke detector/carbon monoxide detector inoperable, repair	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2401 MARITIME WAY	PropID:
RICHMOND, CA 94804-	Client ID: 7024

Dear Current Resident,

This letter is to inform you that your property at **2401 MARITIME WAY RICHMOND**, CA **94804 failed** the Housing Quality Standards (HQS) inspection on 07/18/2025.

A re-inspection has been scheduled for 09/16/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
3.12	Bathroom/Tub or Shower	O
	Tub diverter in 1st floor bedroom is inoperable. Tub runs at same time as	
	shower, repair	
3.3	Bathroom/Electrical Hazards	O
	Install GFCI protected outlet on 2nd level bathroom by sink.	

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2500 SAN MATEO ST	PropID:	
RICHMOND, CA 94804-5618-	Client ID:	7997

Dear Current Resident,

This letter is to inform you that your property at **2500 SAN MATEO ST RICHMOND**, **CA 94804-5618 failed** the Housing Quality Standards (HQS) inspection on 07/18/2025.

A re-inspection has been scheduled for 09/12/2025 between 01:00PM and 04:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
8.1	General Health and Safety/Access to Unit	O
	Install turnstile deadbolt lock on rear door, remove double key entry lock	
2.3	Kitchen/Electrical Hazards	O
	Install GFCI outlet by sink	
3.5	Bathroom/Window Condition	O
	Units will be required to have screens on one exterior window per room, if	
	the window is openable. The screens must be removable for egress in case	
	of an emergency.	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

PropID:

42 BAYSIDE CT RICHMOND, CA 94804-7443-Client ID: 11284

Dear Current Resident,

This letter is to inform you that your property at 42 BAYSIDE CT RICHMOND, CA 94804-7443 failed the Housing Quality Standards (HQS) inspection on 07/18/2025.

A re-inspection has been scheduled for 09/12/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS Tenant/Owner 2.10 Kitchen/Stove or Range with Oven O Microwave/ Range hood inoperable, repair. Unit has been unplugged due to electrical short per tenant. Tenant states owner is aware of issue with range hood.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,