



7/16/2026

FAILED INSPECTION NOTICE

2355 LANCASTER DR Apt 15
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2355 LANCASTER DR Apt 15 RICHMOND, CA 94806-2590** **failed** the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
4.10	Other Rooms/Smoke Detectors Smoke detector is missing. All units must have at least one operable smoke detector in each bedroom and in a common area on each level.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2355 LANCASTER DR Apt 17
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2355 LANCASTER DR Apt 17 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12 Kitchen/Sink	Dishwasher has a leak in front of unit, repair

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2355 LANCASTER DR Apt 18
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2355 LANCASTER DR Apt 18 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2355 LANCASTER DR Apt 19
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2355 LANCASTER DR Apt 19 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
8.6	General Health and Safety/Interior Stairs and Common Halls Common area smoke detector inoperable, replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2355 LANCASTER DR Apt 21
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2355 LANCASTER DR Apt 21 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
2.12	Kitchen/Sink Dishwasher inoperable, repair
2.5	Kitchen/Window Condition Lower fixed window rusted, repair or replace
3.13	Bathroom/Ventilation Vent fan inoperable, repair
3.5	Bathroom/Window Condition Window screen damaged, repair



7/16/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2355 LANCASTER DR Apt 14
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2355 LANCASTER DR Apt 14 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
2.12 Kitchen/Sink	Dishwasher inoperable, repair

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2355 LANCASTER DR Apt 22
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2355 LANCASTER DR Apt 22 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
3.6	Bathroom/Ceiling Condition Clean discoloration on bathroom ceiling
4.10	Other Rooms/Smoke Detectors Replace smoke detector, exceeds 10 year life span

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2355 LANCASTER DR Apt 23
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2355 LANCASTER DR Apt 23 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12	Kitchen/Sink Dishwasher drains through air gap, repair as drain must go through garbage disposal.
8.1	General Health and Safety/Access to Unit Security gate damaged, repair/replace or remove

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2355 LANCASTER DR Apt 24
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2355 LANCASTER DR Apt 24 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
2.10	Kitchen/Stove or Range with Oven Replace rusted drip pans
2.12	Kitchen/Sink Dishwasher drains through air gap, repair as drain must go through garbage disposal.
3.12	Bathroom/Tub or Shower Shower head leaking in rear, repair
3.13	Bathroom/Ventilation Vent fan inoperable, repair
4.10	Other Rooms/Smoke Detectors Smoke detector is missing. All units must have at least one operable smoke detector in each bedroom and in a common area on each level.
8.6	General Health and Safety/Interior Stairs and Common Halls Replace common area smoke detector, exceeds 10 year life span



7/16/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 2
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 2 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 3
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 3 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 4
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 4 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 5
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 5 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12	Kitchen/Sink 1. Faucet as constant drip, repair 2. Dishwasher inoperable, repair
3.13	Bathroom/Ventilation vent fan inoperable, repair
3.6	Bathroom/Ceiling Condition Clean discoloration on ceiling
4.5	Other Rooms/Window Condition 1. Window must be openable and remain open without props. 2. TENANT TO CLEAN DISCOLORATION ON WINDOW & WINDOW SEAL
7.1	Heating and Plumbing/Adequacy of Heating Equipment Living room heater control knob missing, replace
8.2	General Health and Safety/Exits Move furniture blocking patio door (fire exit)
2.10	Kitchen/Stove or Range with Oven hood range rusted and peeling - replace



7/16/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 6
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 6 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 7
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 7 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
4.5	Other Rooms/Window Condition Move bed blocking window (fire exit)
7.1	Heating and Plumbing/Adequacy of Heating Equipment Living room heater control knob missing, replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 8
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 8 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/10/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12	Kitchen/Sink 1. Faucet has constant drip, repair or replace 2. Dishwasher inoperable, sitting water in dishwasher, Repair or replace
3.12	Bathroom/Tub or Shower Resurface tub, peeling paint present
4.10	Other Rooms/Smoke Detectors Smoke detector is missing. All units must have at least one operable smoke detector in each bedroom and in a common area on each level.



7/16/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 11
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 11 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/10/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 15
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 15 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/10/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 16
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 16 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/10/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12 Kitchen/Sink	Dishwasher drains through air gap, repair as drain must go through garbage disposal.
2.5 Kitchen/Window Condition	Lower fixed window rusted, repair or replace
2.7 Kitchen/Wall Condition	Repair crack on wall right side of window
4.5 Other Rooms/Window Condition	Address discoloration in between window panels, tenant is unable to remove discoloration as it is not surface level



7/16/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 17
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 17 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/10/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 18
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 18 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/10/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
1.7	Living Room/Wall Condition Repair crack on right wall
2.3	Kitchen/Electrical Hazards Install GFCI protected receptacles by sink
3.12	Bathroom/Tub or Shower Resurface tub, peeling paint present

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 20
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 20 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/10/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
1.6	Living Room/Ceiling Condition Repair/ repaint ceiling. Evidence of water damage present
1.7	Living Room/Wall Condition Repair large cracks on walls
2.3	Kitchen/Electrical Hazards 1. Install GFCI protected receptacles by sink 2. Replace damaged receptacle left of sink, replace with GFCI
2.6	Kitchen/Ceiling Condition Ceiling fan has severe wobbling while in use, repair or replace
2.7	Kitchen/Wall Condition Repair peeling paint on walls
3.13	Bathroom/Ventilation Vent fan inoperable, repair
3.7	Bathroom/Wall Condition Light fixture severely rusted, replace
4.5	Other Rooms/Window Condition Address discoloration on window as it is not on surface level for tenant to clean



7/16/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2340 LANCASTER DR Apt 7
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2340 LANCASTER DR Apt 7 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
8.10	General Health and Safety/Site and Neighborhood Conditions patio has overgrowth - cut/remove

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2340 LANCASTER DR Apt 8
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2340 LANCASTER DR Apt 8 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12	Kitchen/Sink dishwasher not working/draining properly - repair/replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2340 LANCASTER DR Apt 10
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2340 LANCASTER DR Apt 10 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
1.4	Living Room/Security clear items form patio for egress to patio door
1.7	Living Room/Wall Condition large amounts of discoloration on ceilings /wall - remove/repair/replace
2.12	Kitchen/Sink dishwasher not working/draining properly - repair/replace
2.13	Kitchen/Space for Storage, Prep and Serving countertops damaged - repair/replace
4.7	Other Rooms/Wall Condition wall and ceiling has large amounts of discoloration organic substance - remove/repair/repaint



7/16/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2350 LANCASTER DR Apt 3
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2350 LANCASTER DR Apt 3 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
3.10	Bathroom/Flush Toilet in Enclosed Room in Unit toilet base loose
4.7	Other Rooms/Wall Condition bedroom screen missing
8.7	General Health and Safety/Other Interior Hazards hallway smoke detector inop

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2350 LANCASTER DR Apt 4
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2350 LANCASTER DR Apt 4 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2360 LANCASTER DR Apt 2
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2360 LANCASTER DR Apt 2 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12	Kitchen/Sink dishwasher not working/draining properly - repair/replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2360 LANCASTER DR Apt 5
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2360 LANCASTER DR Apt 5 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2360 LANCASTER DR Apt 8
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2360 LANCASTER DR Apt 8 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
1.8	Living Room/Floor Condition carpet worn/damaged - repair/replace
2.12	Kitchen/Sink dishwasher not working/draining properly - repair/replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2370 LANCASTER DR Apt 7
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2370 LANCASTER DR Apt 7 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12	Kitchen/Sink dishwasher not working/draining properly - repair/replace
3.10	Bathroom/Flush Toilet in Enclosed Room in Unit toilet base loose
3.7	Bathroom/Wall Condition hole in wall - repair/repaint

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2370 LANCASTER DR Apt 9
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2370 LANCASTER DR Apt 9 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.13	Kitchen/Space for Storage, Prep and Serving drawer front cover missing
3.10	Bathroom/Flush Toilet in Enclosed Room in Unit toilet base loose

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



7/16/2026

FAILED INSPECTION NOTICE

2370 LANCASTER DR Apt 10
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2370 LANCASTER DR Apt 10 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 07/13/2026.

A re-inspection has been scheduled for 09/09/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
1.8	Living Room/Floor Condition carpet worn/damaged - repair/replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program