

FAILED INSPECTION NOTICE

Laouida J Gray 241 Arrowhead Dr Vallejo, CA 94589-1782 Property: 336 WILLARD AVE RICHMOND, CA 94801-1962-

PropID:

Client ID: 3740

Dear Owner/Agent,

This letter is to inform you that your property at **336 WILLARD AVE RICHMOND, CA 94801-1962 failed** the Housing Quality Standards (HQS) inspection on 08/31/2023.

A re-inspection has been scheduled for 10/06/2023 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

2.10 Kitchen/Stove or Range with Oven all burners must self-ignite

Tenant/Owner

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Philip Anthony Schurman 752 Euclid Ave Berkeley, CA 94708 Property: 516 BARRETT AVE RICHMOND, CA 94801-2653-

PropID:

Client ID: 19079

Dear Owner/Agent,

This letter is to inform you that your property at **516 BARRETT AVE RICHMOND, CA 94801-2653 failed** the Housing Quality Standards (HQS) inspection on 08/31/2023.

A re-inspection has been scheduled for 10/06/2023 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
2.10	Kitchen/Stove or Range with Oven	O
	all burners must self-ignite	
7.1	Heating and Plumbing/Adequacy of Heating Equipment	O
	heater inop, repair	

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Herbert & Patricia Yarbrough Sutro Property Management Po Box 885373 San Francisco, CA 94188 Property: 908 VIEW DR RICHMOND, CA 94803-1248-

PropID:

Client ID: 6187

Dear Owner/Agent,

This letter is to inform you that your property at **908 VIEW DR RICHMOND**, CA **94803-1248 failed** the Housing Quality Standards (HQS) inspection on 08/31/2023.

A re-inspection has been scheduled for 10/03/2023 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
7.3	Heating and Plumbing/Ventilation and Adequacy of Cooling	O
	A/C Not Functioning Properly.	
8.10	General Health and Safety/Site and Neighborhood Conditions	O
	cut overgrown vegetaion on property,	

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Holdings 4 Llc Lm Po Box 2248 Fremont, CA 94536 Property: 12557 SAN PABLO AVE RICHMOND, CA 94805-

PropID:

Client ID: 18632

Dear Owner/Agent,

This letter is to inform you that your property at 12557 SAN PABLO AVE RICHMOND, CA 94805 failed the Housing Quality Standards (HQS) inspection on 08/31/2023.

A re-inspection has been scheduled for 10/06/2023 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS 7.1 Heating and Plumbing/Adequacy of Heating Equipment heater inoperable Tenant/Owner O

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Ernesto & Leticia Delamora 5243 Carriage Dr El Sobrante, CA 94803-3856 Property: 3717 NEVIN AVE Apt 4 RICHMOND, CA 94805-2290-

PropID:

Client ID: 6101

Dear Owner/Agent,

This letter is to inform you that your property at **3717 NEVIN AVE Apt 4 RICHMOND, CA 94805-2290 failed** the Housing Quality Standards (HQS) inspection on 08/31/2023.

A re-inspection has been scheduled for 10/06/2023 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS 3.12 Bathroom/Tub or Shower shower enclosure cracked, repair

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Chester R Est Of Fung Discovery Investments Inc 3521 Grand Ave Oakland, CA 94610 Property: 2620 MOYERS RD RICHMOND, CA 94806-

PropID:

Client ID: 17477

Dear Owner/Agent,

This letter is to inform you that your property at **2620 MOYERS RD RICHMOND**, CA **94806 failed** the Housing Quality Standards (HQS) inspection on 08/31/2023.

A re-inspection has been scheduled for 10/06/2023 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS 7.4 Heating and Plumbing/Water Heater install pressure release valve pipe

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,