

FAILED INSPECTION NOTICE

873 7TH ST RICHMOND, CA 94801-2218-

Client ID: 9817

PropID:

Dear Current Resident,

This letter is to inform you that your property at **873 7TH ST RICHMOND**, **CA 94801-2218 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 8.6 General Health and Safety/Interior Stairs and Common Halls
 Repair crack on ceiling above heater in hallway. Evidence of previous water damage
- 1.4 Living Room/SecurityInstall striker plate on door frame for deadbolt lock
- 6.4 Building Exterior/Condition of Exterior Surfaces
 Exterior dryer vent cover damaged, replace



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

759 15TH ST RICHMOND, CA 94801-2453-

Client ID: 3872

PropID:

Dear Current Resident,

This letter is to inform you that your property at **759 15TH ST RICHMOND**, CA **94801-2453 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 5.3 Secondary Rooms/Electrical Hazards Replace cracked outlet in laundry room by sink. Outlet also has open grounds, repair or install GFCI
- 8.4 General Health and Safety/Garbage and Debris Remove old appliances and furniture in yard
- 7.1 Heating and Plumbing/Adequacy of Heating Equipment Heater inoperable, repair
- 2.11 Kitchen/Refrigerator Light inoperable, repair



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

1835 GAYNOR AVE RICHMOND, CA 94801-2534-

Dear Current Resident,

Client ID: 9722

PropID:

This letter is to inform you that your property at **1835 GAYNOR AVE RICHMOND**, **CA 94801-2534 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.



FAILED INSPECTION NOTICE

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

7.1 Heating and Plumbing/Adequacy of Heating Equipment Heater inoperable, repair

Secure thermostat to wall

- 2.10 Kitchen/Stove or Range with Oven
 - 1- Replace missing range hood vent screen/filter
 - 2- Center burner inoperable, repair
- 4.3 Other Rooms/Elecrtical Hazards
 Light switch coverplate missing, replace
- 4.10 Other Rooms/Smoke Detectors

Smoke detector is inoperable or missing. All units must have at least one operable smoke detector on each level. The smoke detector must be placed according to package insturctions.

- 3.12 Bathroom/Tub or Shower
 - Shower head leaking, repair
- 3.13 Bathroom/Ventilation
 - Clean excessive dust build up on vent fan
- 8.6 General Health and Safety/Interior Stairs and Common Halls Common area smoke detector batteries removed, replace
- 8.4 General Health and Safety/Garbage and Debris
 - Remove old refrigerator in yard
- 8.2 General Health and Safety/Exits

Clear items on exterior of unit blocking bedroom window exits

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

1835 GAYNOR AVE Apt 1/2 RICHMOND, CA 94801-2534PropID:

Client ID: 9722

Dear Current Resident,

This letter is to inform you that your property at **1835 GAYNOR AVE Apt 1/2 RICHMOND, CA 94801-2534 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.



FAILED INSPECTION NOTICE

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 8.7 General Health and Safety/Other Interior Hazards Common area smoke detector batteries removed, replace
- 7.1 Heating and Plumbing/Adequacy of Heating Equipment
 - 1- Heater inoperable, repair
 - 2- Thermostat cover missing, replace
- 4.10 Other Rooms/Smoke Detectors

Smoke detector is inoperable or missing. All units must have at least one operable smoke detector on each level. The smoke detector must be placed according to package insturctions.

- 4.3 Other Rooms/Electrical Hazards
 Outlets have open grounds, repair
- 2.3 Kitchen/Electrical Hazards
 Outlet left of refrigerator has hot/ neutral reverse, repair
- 2.12 Kitchen/Sink

Subfloor underneath kitchen sink damaged, replace

- 8.1 General Health and Safety/Access to Unit
 Install deadbolt lock on rear door that leads to exterior
- 4.5 Other Rooms/Window Condition

Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

1905 GAYNOR AVE RICHMOND, CA 94801-2534PropID:

Client ID: 9722

Dear Current Resident,

This letter is to inform you that your property at 1905 GAYNOR AVE RICHMOND, CA 94801-2534 failed the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 8.6 General Health and Safety/Interior Stairs and Common Halls Common area smoke detector removed, replace
- 7.1 Heating and Plumbing/Adequacy of Heating Equipment Heater inoperable, repair

Thermostat cover missing, replace

- 2.12 Kitchen/Sink
 - Faucet leaking in center, repair or replace
- 2.3 Kitchen/Electrical Hazards
 - Outlet by door has open grounds, repair

Secure outlet behind stove

- 3.11 Bathroom/Fixed Wash Basin or Lavatory in Unit
 - No hot water at bathroom sink, repair
- 3.12 Bathroom/Tub or Shower
 - Tub/Shower Faucet Knob(s) Damaged / Missing.
 - Unable to test shower during inspection as knobs missing, replace
- 8.7 General Health and Safety/Other Interior Hazards
 - Install carbon monoxide detector in unit



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

1803 ROOSEVELT AVE RICHMOND, CA 94801-2836PropID:

Client ID: 8884

Dear Current Resident,

This letter is to inform you that your property at **1803 ROOSEVELT AVE RICHMOND**, **CA 94801-2836 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 5.4 Secondary Rooms/Other Potential Hazardous Features
 Dining room window screen damaged, repair
- 5.3 Secondary Rooms/Electrical Hazards
 Dining room outlet has hot/nuetral reverse, repair
- 7.1 Heating and Plumbing/Adequacy of Heating Equipment Heater inoperable, repair
- 4.10 Other Rooms/Smoke Detectors Smoke detector is inoperable or missing. All units must have at least one operable smoke detector on each level. The smoke detector must be placed according to package insturctions.
- 4.3 Other Rooms/Elecrtical Hazards
 Clear items in room to allow access to outlets for inspection
- 4.5 Other Rooms/Window Condition

 Move items blocking window (fire exit)
- 8.1 General Health and Safety/Access to Unit Rear screen door damaged, repair or remove



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

637 16TH ST RICHMOND, CA 94801-2843-

Client ID: 9817

PropID:

Dear Current Resident,

This letter is to inform you that your property at **637 16TH ST RICHMOND**, **CA 94801-2843 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 4.5 Other Rooms/Window Condition Install quick release for security bars, or remove. Tenant must be able to exit room in emergency
- 3.12 Bathroom/Tub or Shower
 Resurface tub, rust present throughout
- 2.12 Kitchen/Sink
 Resurface kitchen sink, rust present inside of sink



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

652 15TH ST RICHMOND, CA 94801-2899PropID: Client ID: 8599

Dear Current Resident,

This letter is to inform you that your property at **652 15TH ST RICHMOND**, CA **94801-2899 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 7.4 Heating and Plumbing/Water Heater Earthquake straps needed on top and bottom.
- 6.4 Building Exterior/Condition of Exterior Surfaces
 Exterior vent screen missing across from carport, replace
- 4.5 Other Rooms/Window ConditionMove furniture blocking access to window (fire exit)
- 4.3 Other Rooms/Elecrtical Hazards
 A missing and/or cracked coverplate presents an electrical hazard. Replace missing cover plate on left wall
- 3.12 Bathroom/Tub or Shower
 Resurface tub, peeling paint/rust present



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

654 15TH ST RICHMOND, CA 94801-2899PropID:

Client ID: 8599

Dear Current Resident,

This letter is to inform you that your property at **654 15TH ST RICHMOND**, CA **94801-2899 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 7.4 Heating and Plumbing/Water Heater Earthquake straps needed on top and bottom.
- 6.4 Building Exterior/Condition of Exterior Surfaces
 Replace missing exterior vent cover across from carport
- 1.3 Living Room/Electrical Hazards
 Three prong outlet not testing as designed, must be grounded, replaced with a
 two-prong outlet or replaced with a GFCI.
- 4.3 Other Rooms/Elecrtical Hazards
 Three prong outlet not testing as designed, must be grounded, replaced with a
 two-prong outlet or replaced with a GFCI.



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

656 15TH ST RICHMOND, CA 94801-2899PropID:

Client ID: 8599

Dear Current Resident,

This letter is to inform you that your property at **656 15TH ST RICHMOND**, CA **94801-2899 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 8.7 General Health and Safety/Other Interior Hazards
 Install carbon monoxide detector inside of unit
- 7.4 Heating and Plumbing/Water Heater Earthquake straps needed on top and bottom.
- 6.4 Building Exterior/Condition of Exterior Surfaces
 Replace missing exterior vent screen across from carport
- 4.10 Other Rooms/Smoke DetectorsReplace, current smoke detector exceeds 10 year life span
- 3.3 Bathroom/Electrical Hazards
 Install GFCI protected outlet above sink
- 4.4 Other Rooms/Security
 Remove keyed lock from interior door.



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

546 21ST ST PropID: RICHMOND, CA 94801-3320- Client ID: 9817

Dear Current Resident,

This letter is to inform you that your property at **546 21ST ST RICHMOND**, CA **94801-3320 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 8.4 General Health and Safety/Garbage and Debris Remove excessive recycling in rear yard
- 3.12 Bathroom/Tub or Shower

 Tub diverter inoperable as tub runs at same time as shower, repair
- 4.5 Other Rooms/Window Condition

 Move furniture blocking window (fire exit)
- 6.4 Building Exterior/Condition of Exterior Surfaces
 Replace missing rear exterior weatherproof outlet cover



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

621 21ST ST PropID: RICHMOND, CA 94801-3321- Client ID: 8884

Dear Current Resident,

This letter is to inform you that your property at **621 21ST ST RICHMOND**, CA **94801-3321 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.



FAILED INSPECTION NOTICE

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 6.2 Building Exterior/Condition of Stairs, Rails, and Porches Front exterior steps = Concrete Damaged. Repair
 - Install handrail on front stairs, four or more stairs present
- 8.1 General Health and Safety/Access to Unit Install patio door screen
- 4.10 Other Rooms/Smoke Detectors
 Replace, exceeds 10 year life span
- 3.13 Bathroom/Ventilation
 Clean vent fan, excessive dust build up
- 3.12 Bathroom/Tub or Shower Unable to inspect tub, full of personal items. Remove for inspection.
- Living Room/Wall Condition
 Repair cracks on wall leading to kitchen
- 3.3 Bathroom/Electrical Hazards
 GFCI has hot/ neutral reverse, repair
- 2.10 Kitchen/Stove or Range with Oven Range hood rusted/peeling paint. Replace or remove
- 4.5 Other Rooms/Window ConditionMove items blocking access to window (fire exit)
- 4.3 Other Rooms/Elecrtical Hazards
 No access to outlets, tenant to clear items to allow access for inspection

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

820 VIRGINIA AVE Apt 3 RICHMOND, CA 94804-2465-

.

PropID:

Client ID: 8312

Dear Current Resident,

This letter is to inform you that your property at **820 VIRGINIA AVE Apt 3 RICHMOND, CA 94804-2465 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/07/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

8.6 General Health and Safety/Interior Stairs and Common Halls No smoke detector in common area, install.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

820 VIRGINIA AVE Apt 1 RICHMOND, CA 94804-2465PropID:

Client ID: 8312

Dear Current Resident,

This letter is to inform you that your property at **820 VIRGINIA AVE Apt 1 RICHMOND, CA 94804-2465 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/07/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 2.10 Kitchen/Stove or Range with Oven Top right burner not operable, repair.
- 2.5 Kitchen/Window Condition
 Kitchen window screen missing, replace.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

423 S 16TH ST Apt 1 RICHMOND, CA 94804-2567PropID:

Client ID: 8518

Dear Current Resident,

This letter is to inform you that your property at 423 S 16TH ST Apt 1 RICHMOND, CA 94804-2567 failed the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/08/2025 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

4.10 Other Rooms/Smoke DetectorsNo smoke detector in 2nd bedroom, install.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

3726 OHIO AVE RICHMOND, CA 94804-3325PropID:

Client ID: 9722

Dear Current Resident,

This letter is to inform you that your property at **3726 OHIO AVE RICHMOND**, CA **94804-3325 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/10/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 8.4 General Health and Safety/Garbage and Debris

 Declutter unit, excessive amount of trash on floors throughout unit
- 8.3 General Health and Safety/Evidence of Infestation Exterminate for roaches.
- 4.10 Other Rooms/Smoke Detectors Smoke detector is missing. All units must have at least one operable smoke detector in each bedroom and in a common area on each level.
- 8.6 General Health and Safety/Interior Stairs and Common Halls Common area smoke detector removed, replace
- 8.7 General Health and Safety/Other Interior Hazards
 Install carbon monoxide detector in unit
- 3.1 Bathroom/Bathroom Present
 NO ACCESS, IN USE DURING INSPECTION.



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

238 S 43RD ST RICHMOND, CA 94804-3406-

Client ID: 8319

PropID:

Dear Current Resident,

This letter is to inform you that your property at **238 S 43RD ST RICHMOND**, CA **94804-3406 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/07/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

2.10 Kitchen/Stove or Range with Oven

Kitchen stove not working properly:

- 1. All four burners does not self ignite, repair.
- 2. Stove does not heat up, repair.
- 3. Screen not operable, repair/replace.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

236 S 43RD ST RICHMOND, CA 94804-3406PropID:

Client ID: 8319

Dear Current Resident,

This letter is to inform you that your property at **236 S 43RD ST RICHMOND**, CA **94804-3406 failed** the Housing Quality Standards (HQS) inspection on 08/13/2025.

A re-inspection has been scheduled for 10/07/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 8.6 General Health and Safety/Interior Stairs and Common Halls No smoke detector in common area, install.
- 4.10 Other Rooms/Smoke Detectors

 Smoke detector in left front bedroom non operable, repair/replace.
- 2.13 Kitchen/Space for Storage, Prep and Serving
 - 1. Kitchen missing two cabinet doors, 1 cabinet door deteriorating replace/repair.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,