

FAILED INSPECTION NOTICE

731 8TH ST PropID: RICHMOND, CA 94801-2222- Client ID: 8830

Dear Current Resident,

This letter is to inform you that your property at **731 8TH ST RICHMOND**, CA **94801-2222 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 4.5 Other Rooms/Window Condition replace missing screens
- 4.4 Other Rooms/Security remove key lock
- 8.4 General Health and Safety/Garbage and Debris remove garbage from yard.



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

257 1ST ST PropID: RICHMOND, CA 94801-3442- Client ID: 8281

Dear Current Resident,

This letter is to inform you that your property at **257 1ST ST RICHMOND**, CA **94801-3442 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 8.10 General Health and Safety/Site and Neighborhood Conditions cut overgrown grass.
 - remove old appliances garage and debris
- 4.5 Other Rooms/Window Condition replace missing screens
- 4.4 Other Rooms/Security remove keylock



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

21 11TH ST RICHMOND, CA 94801-3521PropID:

Client ID: 8830

Dear Current Resident,

This letter is to inform you that your property at **21 11TH ST RICHMOND**, CA 94801-3521 failed the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

4.4 Other Rooms/Security remove keylocks

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

25 19TH ST RICHMOND, CA 94801-3694PropID:

Client ID: 3117

Dear Current Resident,

This letter is to inform you that your property at **25 19TH ST RICHMOND**, CA **94801-3694 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

6.4 Building Exterior/Condition of Exterior Surfaces
Peeling and chipping paint on 90% of building. repaint

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

27 19TH ST RICHMOND, CA 94801-3694-

.. -- **244**-

Client ID: 3117

PropID:

Dear Current Resident,

This letter is to inform you that your property at **27 19TH ST RICHMOND**, **CA 94801-3694 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

6.4 Building Exterior/Condition of Exterior Surfaces chipping and peeling paint on 90% of building

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

29 19TH ST RICHMOND, CA 94801-3694-

Client ID: 3117

PropID:

Dear Current Resident,

This letter is to inform you that your property at **29 19TH ST RICHMOND**, CA **94801-3694 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

6.4 Building Exterior/Condition of Exterior Surfaces chipping and peeling paint on 90% of building

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

31 19TH ST RICHMOND, CA 94801-3694PropID: Client ID: 3117

Dear Current Resident,

This letter is to inform you that your property at **31 19TH ST RICHMOND**, CA **94801-3694 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

6.4 Building Exterior/Condition of Exterior Surfaces chipping and peeling paint on 90% of building

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

244 PARK LN RICHMOND, CA 94803-1224-

Client ID: 2586

PropID:

Dear Current Resident,

This letter is to inform you that your property at **244 PARK LN RICHMOND**, CA **94803-1224 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/13/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 2.12 Kitchen/Sink
 - Dishwasher drains through air gap, repair as drain must go through garbage disposal.
- 6.4 Building Exterior/Condition of Exterior Surfaces
 Exterior outlet missing weatherproof cover, install

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

5061 ESCALON CIR RICHMOND, CA 94803-2055-

. -- 0.4**-**-

Client ID: 9476

PropID:

Dear Current Resident,

This letter is to inform you that your property at **5061 ESCALON CIR RICHMOND, CA 94803-2055 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/13/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 2.10 Kitchen/Stove or Range with Oven Right burners not self lighting, repair
- 2.12 Kitchen/Sink
 Garbage disposal inoperable, repair
- 4.4 Other Rooms/Security
 Remove keyed lock from interior door.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

3801 HIDDEN SPRINGS RICHMOND, CA 94803-2146PropID:

Client ID: 9476

Dear Current Resident,

This letter is to inform you that your property at **3801 HIDDEN SPRINGS RICHMOND**, CA **94803-2146 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/13/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 8.6 General Health and Safety/Interior Stairs and Common Halls Replace cracked outlet at top of stairwell
- 4.4 Other Rooms/Security
 Remove keyed lock from interior door.
- 4.5 Other Rooms/Window Condition
 Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
- 3.3 Bathroom/Electrical Hazards
 Install GFCI receptacle by right sink in master bedroom level 2
- 3.5 Bathroom/Window Condition Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
 - MASTER BEDROOM LEVEL 2
- 2.10 Kitchen/Stove or Range with Oven Replace missing range hood light bulb
- 5.2 Secondary Rooms/Security
 Install patio door screen



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

17 QUAIL HILL LN RICHMOND, CA 94803-2833PropID:

Client ID: 9601

Dear Current Resident,

This letter is to inform you that your property at 17 QUAIL HILL LN RICHMOND, CA 94803-2833 failed the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 3.3 Bathroom/Electrical Hazards
 Install GFCI receptacles by left and right sink in master bedroom
- 4.10 Other Rooms/Smoke Detectors Smoke dectector is missing battery or batteries. Tenants are responsible for replacement of batteries in all smoke detectors in the unit.
- 4.3 Other Rooms/Elecrtical Hazards
 Replace cracked outlet underneath left window



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

236 S 5TH ST RICHMOND, CA 94804-

Client ID: 8830

PropID:

Dear Current Resident,

This letter is to inform you that your property at **236 S 5TH ST RICHMOND**, **CA 94804 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

8.4 General Health and Safety/Garbage and Debris remove garbage from front and backyard old appliances and old paint

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

3809 MORNINGSIDE DR RICHMOND, CA 94804PropID:

Client ID: 9476

Dear Current Resident,

This letter is to inform you that your property at **3809 MORNINGSIDE DR RICHMOND**, **CA 94804 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/13/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 8.6 General Health and Safety/Interior Stairs and Common Halls Replace cracked outlet located across from stairwell.
- 4.4 Other Rooms/Security
 Remove keyed lock from interior door.
- 4.3 Other Rooms/Elecrtical Hazards
 Outlet on left wall missing cover plate, replace
- 1.3 Living Room/Electrical Hazards
 Replace cracked outlet underneath left window
- 2.12 Kitchen/Sink

Resurface kitchen sink

8.10 General Health and Safety/Site and Neighborhood Conditions Cut down weeds in yard



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2348 RHEEM AVE RICHMOND, CA 94804-1018PropID: Client ID: 8970

Dear Current Resident,

This letter is to inform you that your property at **2348 RHEEM AVE RICHMOND, CA 94804-1018 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.



FAILED INSPECTION NOTICE

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 8.4 General Health and Safety/Garbage and Debris Remove old appliances and bedding from shared yard
- 8.7 General Health and Safety/Other Interior Hazards Hall light inoperable, repair
- 3.3 Bathroom/Electrical Hazards

Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.

- 3.11 Bathroom/Fixed Wash Basin or Lavatory in Unit Recaulk behind bathroom sink
- 3.12 Bathroom/Tub or Shower Resurface tub
- 3.6 Bathroom/Ceiling Condition
 Clean moisture condensation on ceiling
- 3.5 Bathroom/Window Condition

Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.

4.10 Other Rooms/Smoke Detectors

Smoke detector is missing. All units must have at least one operable smoke detector in each bedroom and in a common area on each level.

4.3 Other Rooms/Elecrtical Hazards

Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.

- 7.1 Heating and Plumbing/Adequacy of Heating Equipment Heater inoperable, repair
- 2.5 Kitchen/Window Condition

Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.

2.3 Kitchen/Electrical Hazards

Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.

2.10 Kitchen/Stove or Range with Oven

Right rear burner knob missing, replace

Clean grease splatter on backsplash



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2350 RHEEM AVE RICHMOND, CA 94804-1018-

· -- --

Client ID: 8970

PropID:

Dear Current Resident,

This letter is to inform you that your property at **2350 RHEEM AVE RICHMOND**, CA **94804-1018 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 4.10 Other Rooms/Smoke Detectors Smoke detector is inoperable or missing. All units must have at least one operable smoke detector on each level. The smoke detector must be placed according to package insturctions.
- 8.4 General Health and Safety/Garbage and Debris
 Remove old appliances and bedding from shared yard

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2352 RHEEM AVE RICHMOND, CA 94804-1018PropID:

Client ID: 8970

Dear Current Resident,

This letter is to inform you that your property at 2352 RHEEM AVE RICHMOND, CA 94804-1018 failed the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.



FAILED INSPECTION NOTICE

- 4.3 Other Rooms/Elecrtical Hazards
 - Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.
- 3.4 Bathroom/Security
 - Remove keyed entry lock from door
- 3.10 Bathroom/Flush Toilet in Enclosed Room in Unit Bath Toilet not secured properly to floor.
- 3.12 Bathroom/Tub or Shower
 - Resurface tub
- 3.5 Bathroom/Window Condition
 - Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
- 3.3 Bathroom/Electrical Hazards
 - GFCI will not reset, replace
- 8.4 General Health and Safety/Garbage and Debris
 - Remove old appliances and bedding from shared yard
- 2.4 Kitchen/Security
 - Remove keyed entry lock from kitchen door
- 2.10 Kitchen/Stove or Range with Oven
 - Front right burner inoperable, repair
- 1.3 Living Room/Electrical Hazards
 - Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2354 RHEEM AVE RICHMOND, CA 94804-1018PropID: Client ID: 8970

Dear Current Resident,

This letter is to inform you that your property at **2354 RHEEM AVE RICHMOND, CA 94804-1018 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 8.4 General Health and Safety/Garbage and Debris Remove old appliances and bedding in shared yard
- 1.3 Living Room/Electrical Hazards Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.
- 1.8 Living Room/Floor Condition Flooring heavily soiled, clean carpet
- 7.1 Heating and Plumbing/Adequacy of Heating Equipment Heater inoperable, repair
- 4.3 Other Rooms/Elecrtical Hazards
 - Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.
- 3.10 Bathroom/Flush Toilet in Enclosed Room in Unit Bath Toilet not secured properly to floor.
- 3.13 Bathroom/Ventilation
 - Clean dust build up on vent fan
- 2.3 Kitchen/Electrical Hazards
 - Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2360 RHEEM AVE RICHMOND, CA 94804-1018-

· -- --

Client ID: 8970

PropID:

Dear Current Resident,

This letter is to inform you that your property at **2360 RHEEM AVE RICHMOND, CA 94804-1018 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.



FAILED INSPECTION NOTICE

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 3.5 Bathroom/Window Condition
 Exterior window trim removed, replace
 - 2- Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
 - 3- Window must be openable and remain open without props.
- 1.8 Living Room/Floor Condition

Flooring torn in living room and hallway, repair

3.3 Bathroom/Electrical Hazards

Install GFCI outlet by sink

3.10 Bathroom/Flush Toilet in Enclosed Room in Unit

Flush mechanism is missing or deteriorated. This represents a major defect which must be corrected.

3.12 Bathroom/Tub or Shower

Tub/Shower Faucet Knob(s) Damaged / Missing.

4.3 Other Rooms/Elecrtical Hazards

Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.

4.10 Other Rooms/Smoke Detectors

Smoke detector is missing. All units must have at least one operable smoke detector in each bedroom and in a common area on each level.

2.3 Kitchen/Electrical Hazards

Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.

2.11 Kitchen/Refrigerator

Exterior of refrigerator rusted, repair

Door handles missing, replace

2.6 Kitchen/Ceiling Condition

Replace/Install missing light fixture cover

1.3 Living Room/Electrical Hazards

Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.

6.4 Building Exterior/Condition of Exterior Surfaces

Crawlspace door by front stairs missing cover, replace



FAILED INSPECTION NOTICE

8.4 General Health and Safety/Garbage and Debris
Remove old appliances and bedding from shared yard

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2362 RHEEM AVE RICHMOND, CA 94804-1018PropID:

Client ID: 8970

Dear Current Resident,

This letter is to inform you that your property at **2362 RHEEM AVE RICHMOND, CA 94804-1018 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.



FAILED INSPECTION NOTICE

- 1.3 Living Room/Electrical Hazards
 - Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.
- 3.5 Bathroom/Window Condition
- Window must be openable and remain open without props.
 4.3 Other Rooms/Elecrtical Hazards
- 4.3 Other Rooms/Elecrtical Hazards
 Three prong outlet not testing as designed, must be grounded, replaced with a
 two-prong outlet or replaced with a GFCI.
- 4.5 Other Rooms/Window Condition
 - Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
- 7.4 Heating and Plumbing/Water Heater install discharge pipe, within 6" of floor.
- 8.1 General Health and Safety/Access to Unit Secure hinge on rear door
- 8.2 General Health and Safety/Exits

 Move items blocking access to bedroom window (fire exit)
- 2.5 Kitchen/Window Condition
 - Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
- 8.4 General Health and Safety/Garbage and DebrisRemove old appliances and bedding from shared yard



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2364 RHEEM AVE RICHMOND, CA 94804-1018-

· -- --

Client ID: 8970

PropID:

Dear Current Resident,

This letter is to inform you that your property at **2364 RHEEM AVE RICHMOND, CA 94804-1018 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 3.5 Bathroom/Window Condition
 - Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
- 1.3 Living Room/Electrical Hazards
 Three prong outlet not testing as designed, must be grounded, replaced with a
- 4.3 Other Rooms/Elecrtical Hazards
 Three prong outlet not testing as designed, must be grounded, replaced with a
 two-prong outlet or replaced with a GFCI.
- 4.5 Other Rooms/Window Condition

two-prong outlet or replaced with a GFCI.

- Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
- 7.5 Heating and Plumbing/Water Supply
 Low water pressure in bathroom at tub
- 3.12 Bathroom/Tub or Shower Resurface tub



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2366 RHEEM AVE RICHMOND, CA 94804-1018PropID:

Client ID: 8970

Dear Current Resident,

This letter is to inform you that your property at **2366 RHEEM AVE RICHMOND, CA 94804-1018 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 1.3 Living Room/Electrical Hazards
 - Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.
- 4.3 Other Rooms/Elecrtical Hazards
 - Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.
- 4.10 Other Rooms/Smoke Detectors
 - Smoke detector is missing. All units must have at least one operable smoke detector in each bedroom and in a common area on each level.
- 8.1 General Health and Safety/Access to Unit
 - Repair rear door, door will not open as designed
- 2.12 Kitchen/Sink
 - Recaulk kitchen sink
- 2.3 Kitchen/Electrical Hazards
 - A missing and/or cracked coverplate presents an electrical hazard. Light switch and outlet both missing cover plates, replace
- 8.4 General Health and Safety/Garbage and Debris
 Remove old appliances and bedding from shared yard



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2443 ESMOND AVE RICHMOND, CA 94804-1309-

11 ID 0601

Client ID: 9601

PropID:

Dear Current Resident,

This letter is to inform you that your property at **2443 ESMOND AVE RICHMOND, CA 94804-1309 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 4.6 Other Rooms/Celing Condition Window screen torn, repair
- 4.5 Other Rooms/Window Condition
 Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
- 8.4 General Health and Safety/Garbage and Debris
 Remove old appliances being stored on back deck
- 2.10 Kitchen/Stove or Range with Oven Front right burner inoperable, repair
- 3.5 Bathroom/Window Condition Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
- 7.1 Heating and Plumbing/Adequacy of Heating Equipment
 Instal permanent mounted heat source in unit that is adequate for entire source.
 Owner can install baseboard heaters in bedrooms and common area.
- 1.5 Living Room/Window Condition
 Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

2541 GARVIN AVE RICHMOND, CA 94804-1376PropID:

Client ID: 9601

Dear Current Resident,

This letter is to inform you that your property at **2541 GARVIN AVE RICHMOND, CA 94804-1376 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 4.4 Other Rooms/Security
 Remove keyed lock from interior door. REMOVE DIGITAL ENTRY LOCK
- 4.10 Other Rooms/Smoke Detectors Smoke detector is inoperable or missing. All units must have at least one operable smoke detector on each level. The smoke detector must be placed according to package insturctions. REPLACE, exceeds 10 year life span
- 4.6 Other Rooms/Celing Condition
 Clean heavy yellow discoloration on ceiling
- 4.7 Other Rooms/Wall Condition
 Clean heavy yellow discoloration on patio door /window
- 4.5 Other Rooms/Window Condition
 Clear items blocking patio door (fire exit)
- 2.10 Kitchen/Stove or Range with Oven Burners not self lighting, repair



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

253 S 4TH ST RICHMOND, CA 94804-2203PropID:

Client ID: 8830

Dear Current Resident,

This letter is to inform you that your property at **253 S 4TH ST RICHMOND, CA 94804-2203 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.



FAILED INSPECTION NOTICE

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

4.5 Other Rooms/Window Condition remove key lock

window hard to open repair or replace

3.5 Bathroom/Window Condition replace missing screens

replace broken window

4.4 Other Rooms/Security remove key lock

4.10 Other Rooms/Smoke Detectors replace smoke detector

4.6 Other Rooms/Celing Condition remove black discoloration from ceiling

5.2 Secondary Rooms/Security remove keylock

8.4 General Health and Safety/Garbage and Debris remove garbage and debris from back side of house.

2.10 Kitchen/Stove or Range with Oven chipping and peeling paint on range hood. repaint or replace

2.5 Kitchen/Window Condition sliding glass door hard to open repair or replace.

replace missing screens

3.3 Bathroom/Electrical Hazards non working gfci outlet repair or replace.

8.6 General Health and Safety/Interior Stairs and Common Halls replace missing smoke and CO detector

1.4 Living Room/Security torn security door repair or replace



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

328 S 28TH ST RICHMOND, CA 94804-2938-

.

Client ID: 8830

PropID:

Dear Current Resident,

This letter is to inform you that your property at **328 S 28TH ST RICHMOND**, CA **94804-2938 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 4.4 Other Rooms/Security remove key lock
- 4.5 Other Rooms/Window Condition replace missing screens
- 3.12 Bathroom/Tub or Shower chipping and peeling and deteriorating caulking. resurface and recaulk
- 3.11 Bathroom/Fixed Wash Basin or Lavatory in Unit broken medicine cabinet repair replaces or remove.



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

424 S 49TH ST Apt 1 RICHMOND, CA 94804-3478PropID:

Client ID: 8970

Dear Current Resident,

This letter is to inform you that your property at 424 S 49TH ST Apt 1 RICHMOND, CA 94804-3478 failed the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 4.3 Other Rooms/Elecrtical Hazards
 Replace cracked receptacle underneath window
- 4.4 Other Rooms/Security

 Remove keyed lock from interior door. Remove key lock from closet door
- 7.4 Heating and Plumbing/Water Heater
 Earthquake straps needed on top and bottom.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

424 S 49TH ST Apt 2 RICHMOND, CA 94804-3478PropID:

Client ID: 8970

Dear Current Resident,

This letter is to inform you that your property at **424 S 49TH ST Apt 2 RICHMOND**, **CA 94804-3478 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 4.10 Other Rooms/Smoke Detectors
 - Smoke detector is inoperable or missing. All units must have at least one operable smoke detector on each level. The smoke detector must be placed according to package insturctions.
- 8.6 General Health and Safety/Interior Stairs and Common Halls

 Common area smoke detector/carbon monoxide detector inoperable, replace
- 6.1 Building Exterior/Condition of Foundation Fill cracks in rear yard, potential tripping hazard
- 8.10 General Health and Safety/Site and Neighborhood Conditions Shared fencing missing boards, replace
- 7.4 Heating and Plumbing/Water Heater Earthquake straps needed on top and bottom.

install discharge pipe, within 6" of floor.



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

424 S 49TH ST Apt 3 RICHMOND, CA 94804-3478PropID:

Client ID: 8970

Dear Current Resident,

This letter is to inform you that your property at **424 S 49TH ST Apt 3 RICHMOND**, **CA 94804-3478 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 7.4 Heating and Plumbing/Water Heater Install discharge pipe, within 6" of floor.
- 7.1 Heating and Plumbing/Adequacy of Heating Equipment Heater inoperable, repair.
- 8.7 General Health and Safety/Other Interior Hazards Hall light inoperable, repair
- 3.12 Bathroom/Tub or Shower
 Tub/Shower Faucet Knob(s) Damaged / Missing.
- 8.1 General Health and Safety/Access to Unit Replace missing patio light bulb
- 6.4 Building Exterior/Condition of Exterior Surfaces
 Exterior outlet missing weatherproof cover, install
- 8.10 General Health and Safety/Site and Neighborhood Conditions Shared fencing missing boards, replace



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

101 SCHOONER RICHMOND, CA 94804-4520PropID:

Client ID: 9601

Dear Current Resident,

This letter is to inform you that your property at **101 SCHOONER RICHMOND**, CA **94804-4520 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 2.12 Kitchen/Sink
 - Secure faucet to sink
- 2.3 Kitchen/Electrical Hazards
 - GFCI outlet right of sink will not reset, repair or replace
- 6.4 Building Exterior/Condition of Exterior Surfaces
 Replace cracked exterior outlet

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

97 SHORELINE CT RICHMOND, CA 94804-7432PropID:

Client ID: 9601

Dear Current Resident,

This letter is to inform you that your property at **97 SHORELINE CT RICHMOND, CA 94804-7432 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 4.10 Other Rooms/Smoke Detectors Smoke detector is inoperable or missing. All units must have at least one operable smoke detector on each level. The smoke detector must be placed according to package insturctions. REPLACE, exceeds 10 year life span
- 8.6 General Health and Safety/Interior Stairs and Common Halls
 Replace common area smoke detector, exceeds 10 year lifespan. Cover up opening
 on ceiling where old wired smoke detector was located



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

12632 SAN PABLO AVE Apt D RICHMOND, CA 94805-1457-

PropID:

Client ID: 8830

Dear Current Resident,

This letter is to inform you that your property at **12632 SAN PABLO AVE Apt D RICHMOND**, CA **94805-1457 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 1.5 Living Room/Window Condition replace missing screens
- 2.5 Kitchen/Window Condition replace missing screens
- 3.5 Bathroom/Window Condition replace missing screens
- 3.12 Bathroom/Tub or Shower chipped and peeling tile inside tub soap dish area. repair or replace.
- 3.3 Bathroom/Electrical Hazards non working gfci out repair or replace



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

12632 SAN PABLO AVE Apt C RICHMOND, CA 94805-1457PropID:

Client ID: 8830

Dear Current Resident,

This letter is to inform you that your property at 12632 SAN PABLO AVE Apt C RICHMOND, CA 94805-1457 failed the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS

- 2.5 Kitchen/Window Condition replace missing screens.
- 2.3 Kitchen/Electrical Hazards gfci outlet will not trip and reset. repair or replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

12632 SAN PABLO AVE Apt A RICHMOND, CA 94805-1457-

PropID:

Client ID: 8830

Dear Current Resident,

This letter is to inform you that your property at 12632 SAN PABLO AVE Apt A RICHMOND, CA 94805-1457 failed the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/09/2025 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- 2.3 Kitchen/Electrical Hazards open ground outlet replace with gfci
- 1.5 Living Room/Window Condition replace missing screen
- 4.5 Other Rooms/Window Condition replace missing screens
- 3.11 Bathroom/Fixed Wash Basin or Lavatory in Unit stopped up sink. unclog sink sink is becoming detached from wall. repair or replace



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

346 38TH ST RICHMOND, CA 94805-2209PropID:

Client ID: 8970

Dear Current Resident,

This letter is to inform you that your property at **346 38TH ST RICHMOND**, **CA 94805-2209 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.



FAILED INSPECTION NOTICE

- 1.4 Living Room/Security
 - Front security gate damaged, repair or remove
- 4.5 Other Rooms/Window Condition
 - Left window screen damaged, repair
- 1.3 Living Room/Electrical Hazards
 - Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.
- 4.3 Other Rooms/Elecrtical Hazards
 - Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.
- 4.10 Other Rooms/Smoke Detectors
 - Smoke detector is inoperable or missing. All units must have at least one operable smoke detector on each level. The smoke detector must be placed according to package insturctions.
- 8.6 General Health and Safety/Interior Stairs and Common Halls Replace missing common area smoke detector/carbon monoxide detector
- 4.6 Other Rooms/Celing Condition
 - Secure light fixture
- 3.12 Bathroom/Tub or Shower
 - Resurface tub
- 7.1 Heating and Plumbing/Adequacy of Heating Equipment
 - Heater inoperable, repair
- 7.2 Heating and Plumbing/Safety of Heating Equipment
 - Remove items stored directly in front and on top of heater (fire hazard)
- 7.4 Heating and Plumbing/Water Heater
 - Earthquake straps needed on top and bottom.
- 5.3 Secondary Rooms/Electrical Hazards
 - Secure laundry room outlets, hanging out of wall. Replace missing cover plates as well.
- 8.1 General Health and Safety/Access to Unit
 - Secure rear door knobs to door
- 2.10 Kitchen/Stove or Range with Oven
 - Burners not self lighting, repair



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

348 38TH ST RICHMOND, CA 94805-2209-

·

PropID:

Client ID: 8970

Dear Current Resident,

This letter is to inform you that your property at **348 38TH ST RICHMOND**, **CA 94805-2209 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.



FAILED INSPECTION NOTICE

- 4.4 Other Rooms/Security
 - Lock striker plate must work and be securely fastened to door frame.
- 4.3 Other Rooms/Elecrtical Hazards
 - Three prong outlet not testing as designed, must be grounded, replaced with a two-prong outlet or replaced with a GFCI.
- 3.5 Bathroom/Window Condition
 - Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
- 4.5 Other Rooms/Window Condition
 - Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
- 7.1 Heating and Plumbing/Adequacy of Heating Equipment Heater inoperable, repair
- 2.10 Kitchen/Stove or Range with Oven Right rear burner inoperable, repair
- 2.5 Kitchen/Window Condition
 - Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
- 7.4 Heating and Plumbing/Water Heater Earthquake straps needed on top and bottom.
- 8.1 General Health and Safety/Access to Unit
 - Tenant to clear items blocking rear door (fire exit)
- 5.4 Secondary Rooms/Other Potential Hazardous Features Flooring torn entering laundry room, repair
- 8.4 General Health and Safety/Garbage and Debris Remove old appliances being stored on patio



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

350 38TH ST RICHMOND, CA 94805-2209PropID:

Client ID: 8970

Dear Current Resident,

This letter is to inform you that your property at **350 38TH ST RICHMOND**, CA **94805-2209 failed** the Housing Quality Standards (HQS) inspection on 08/19/2025.

A re-inspection has been scheduled for 10/15/2025 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

- Living Room/Window Condition
 Window screen damaged, repair
- 4.5 Other Rooms/Window Condition
 Right window screen missing, replace
- 2.11 Kitchen/Refrigerator Refrigerator light inoperable, repair
- 2.5 Kitchen/Window Condition
 Units will be required to have screens on one exterior window per room, if the window is openable. The screens must be removable for egress in case of an emergency.
- 7.1 Heating and Plumbing/Adequacy of Heating Equipment Heater inoperable, repair



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,