



9/10/2025

**FAILED INSPECTION NOTICE**

2601 HILLTOP DR Apt 918  
RICHMOND, CA 94806-5783-

PropID:  
Client ID: 7274

Dear Current Resident,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 918 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 09/05/2025.

**A re-inspection has been scheduled for 11/04/2025 between 11:00AM and 02:00PM.**

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
2.12 Kitchen/Sink	Dishwasher drains through air gap, repair as drain must go through garbage disposal.
2.10 Kitchen/Stove or Range with Oven	Clean grease splatter on stove and range hood

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond  
Residential Rental Inspections Program



9/10/2025

**FAILED INSPECTION NOTICE**

2601 HILLTOP DR Apt 925  
RICHMOND, CA 94806-5783-

PropID:  
Client ID: 7274

Dear Current Resident,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 925 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 09/05/2025.

**A re-inspection has been scheduled for 11/04/2025 between 11:00AM and 02:00PM.**

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.10	Kitchen/Stove or Range with Oven Microwave/range hood handle damaged, repair or replace
3.12	Bathroom/Tub or Shower Shower head leaking, repair (Left bathroom)

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond  
Residential Rental Inspections Program



9/10/2025

**FAILED INSPECTION NOTICE**

2601 HILLTOP DR Apt 931  
RICHMOND, CA 94806-5783-

PropID:  
Client ID: 7274

Dear Current Resident,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 931 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 09/05/2025.

**A re-inspection has been scheduled for 11/04/2025 between 11:00AM and 02:00PM.**

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
7.4	Heating and Plumbing/Water Heater NO ACCESS, LOOSE DOG on patio.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond  
Residential Rental Inspections Program



9/10/2025

**FAILED INSPECTION NOTICE**

2601 HILLTOP DR Apt 935  
RICHMOND, CA 94806-5783-

PropID:  
Client ID: 7274

Dear Current Resident,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 935 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 09/05/2025.

**A re-inspection has been scheduled for 11/04/2025 between 11:00AM and 02:00PM.**

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
2.10	Kitchen/Stove or Range with Oven Rear burners inoperable, repair
8.4	General Health and Safety/Garbage and Debris Tenant to declutter unit
8.6	General Health and Safety/Interior Stairs and Common Halls Right side common area smoke detector/carbon monoxide detector inoperable, replace



9/10/2025

**FAILED INSPECTION NOTICE**

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond  
Residential Rental Inspections Program



9/10/2025

**FAILED INSPECTION NOTICE**

2601 HILLTOP DR Apt 1531  
RICHMOND, CA 94806-5783-

PropID:  
Client ID: 7274

Dear Current Resident,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 1531 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 09/05/2025.

**A re-inspection has been scheduled for 11/04/2025 between 11:00AM and 02:00PM.**

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
3.12 Bathroom/Tub or Shower	Shower head leaking, repair
4.5 Other Rooms/Window Condition	Patio screen torn, repair
2.10 Kitchen/Stove or Range with Oven	Right rear burner inoperable, repair
7.4 Heating and Plumbing/Water Heater	No access, door is locked and tenant states they dont have a key
2.12 Kitchen/Sink	Dishwasher drains through air gap, repair as drain must go through garbage disposal.



9/10/2025

**FAILED INSPECTION NOTICE**

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond  
Residential Rental Inspections Program



9/10/2025

**FAILED INSPECTION NOTICE**

2601 HILLTOP DR Apt 1715  
RICHMOND, CA 94806-5783-

PropID:  
Client ID: 7274

Dear Current Resident,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 1715 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 09/05/2025.

**A re-inspection has been scheduled for 11/04/2025 between 11:00AM and 02:00PM.**

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
7.4	Heating and Plumbing/Water Heater Tenant to clear items stored in hot water heater closet
8.1	General Health and Safety/Access to Unit no show- dog in unit could not enter.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond  
Residential Rental Inspections Program





9/10/2025

**FAILED INSPECTION NOTICE**

2601 HILLTOP DR Apt 1725  
RICHMOND, CA 94806-5783-

PropID:  
Client ID: 7274

Dear Current Resident,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 1725 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 09/05/2025.

**A re-inspection has been scheduled for 11/04/2025 between 11:00AM and 02:00PM.**

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
3.10	Bathroom/Flush Toilet in Enclosed Room in Unit toilet not flushing like designed. repair or replace.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond  
Residential Rental Inspections Program



9/10/2025

**FAILED INSPECTION NOTICE**

2601 HILLTOP DR Apt 1727  
RICHMOND, CA 94806-5783-

PropID:  
Client ID: 7274

Dear Current Resident,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 1727 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 09/05/2025.

**A re-inspection has been scheduled for 11/04/2025 between 11:00AM and 02:00PM.**

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
1.8	Living Room/Floor Condition torn carpet exposed nails near front entrance. repair
2.3	Kitchen/Electrical Hazards GFCI outlet will not trip and reset as designed. repair or replace.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond  
Residential Rental Inspections Program



9/10/2025

**FAILED INSPECTION NOTICE**

2601 HILLTOP DR Apt 1737  
RICHMOND, CA 94806-5783-

PropID:  
Client ID: 7274

Dear Current Resident,

This letter is to inform you that your property at **2601 HILLTOP DR Apt 1737 RICHMOND, CA 94806-5783** failed the Housing Quality Standards (HQS) inspection on 09/05/2025.

**A re-inspection has been scheduled for 11/04/2025 between 11:00AM and 02:00PM.**

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
1.8	Living Room/Floor Condition Carpeting torn at entry, repair
8.3	General Health and Safety/Evidence of Infestation tenant stated that she had bed bugs inside of unit. professional extermination is required or proof that unit has been inspected and is free of bed bugs. did not inspect unit.
1.3	Living Room/Electrical Hazards Outlet at right of entry has no power, repair
2.10	Kitchen/Stove or Range with Oven 1- Front right burner inoperable, repair  2- Oven door will not close properly, repair
2.11	Kitchen/Refrigerator Refrigerator light inoperable, repair
3.8	Bathroom/Floor Condition Repair damaged flooring
3.10	Bathroom/Flush Toilet in Enclosed Room in Unit Toilet continues to run once flushed, repair
3.7	Bathroom/Wall Condition Closet doors off track, repair



9/10/2025

## **FAILED INSPECTION NOTICE**

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond  
Residential Rental Inspections Program