



9/14/2026

FAILED INSPECTION NOTICE

4822 CUTTING BLVD
RICHMOND, CA 94804-3497-

PropID:
Client ID: 14674

Dear Current Resident,

This letter is to inform you that your property at **4822 CUTTING BLVD RICHMOND, CA 94804-3497** **failed** the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 10/29/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area	REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS
------	--

8.7	General Health and Safety/Other Interior Hazards install smoke detectors in bedrooms 1-4
-----	---

replace missing CO detector

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

530 S 18TH ST
RICHMOND, CA 94804-3802-

PropID:
Client ID: 9966

Dear Current Resident,

This letter is to inform you that your property at **530 S 18TH ST RICHMOND, CA 94804-3802** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 10/29/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
1.5	Living Room/Window Condition replace missing screen
8.6	General Health and Safety/Interior Stairs and Common Halls replace missing CO detector
1.3	Living Room/Electrical Hazards open ground outlet under window repair or replace.
3.5	Bathroom/Window Condition replace missing screen
4.5	Other Rooms/Window Condition replace missing screens
8.10	General Health and Safety/Site and Neighborhood Conditions Ext. = Overgrown Grass/Weeds.
8.4	General Health and Safety/Garbage and Debris Ext. = Garbage & Debris around Unit.



9/14/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

633 S 29TH ST Apt A
RICHMOND, CA 94804-4053-

PropID:
Client ID: 14667

Dear Current Resident,

This letter is to inform you that your property at **633 S 29TH ST Apt A RICHMOND, CA 94804-4053** **failed** the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 10/29/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
4.4	Other Rooms/Security Remove keyed lock from interior door.
8.7	General Health and Safety/Other Interior Hazards replace non working CO in common area
2.12	Kitchen/Sink Kitchen sink faucet has a leak. and loose. repair or replace
2.10	Kitchen/Stove or Range with Oven non working front left burner. repair or replace range hood fan not working. repair or replace
1.7	Living Room/Wall Condition remove black discoloration from all wall and ceiling around heater
3.10	Bathroom/Flush Toilet in Enclosed Room in Unit Toilet Tank Lid Missing or needs replacement.
3.7	Bathroom/Wall Condition broken mirror repair or replace
3.12	Bathroom/Tub or Shower low water pressure repair or replace.
1.3	Living Room/Electrical Hazards replace missing cover plates on outlet. non working outlet repair or replace



9/14/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

633 S 29TH ST Apt B
RICHMOND, CA 94804-4053-

PropID:
Client ID: 14667

Dear Current Resident,

This letter is to inform you that your property at **633 S 29TH ST Apt B RICHMOND, CA 94804-4053** **failed** the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 10/29/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12	Kitchen/Sink Kitchen sink faucet has a major leak.
2.10	Kitchen/Stove or Range with Oven non working front left burner repair or replace. rangehood fan not working repair or replace
1.7	Living Room/Wall Condition remove black discoloration caused by heater.
3.4	Bathroom/Security broken door repair or replace
3.12	Bathroom/Tub or Shower low water pressure. repair or replace
1.3	Living Room/Electrical Hazards Non-working outlet may be hazardous. repair or replace replace missing cover plate



9/14/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

1428 MONTEREY ST
RICHMOND, CA 94804-4945-

PropID:
Client ID: 11985

Dear Current Resident,

This letter is to inform you that your property at **1428 MONTEREY ST RICHMOND, CA 94804-4945** **failed** the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 10/29/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
8.7	General Health and Safety/Other Interior Hazards replace non working CO detector

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2409 ABERDEEN WAY Apt Unit 6
RICHMOND, CA 94806-

PropID:
Client ID: 12750

Dear Current Resident,

This letter is to inform you that your property at **2409 ABERDEEN WAY Apt Unit 6 RICHMOND, CA 94806** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 10/21/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
8.10	General Health and Safety/Site and Neighborhood Conditions Site security doors inoperable, doors are open and not secured. Repair
8.3	General Health and Safety/Evidence of Infestation Exterminate for roaches. Severe roach infestation throughout unit
8.4	General Health and Safety/Garbage and Debris Remove excessive trash on exterior of site. Scattered trash in rear of complex. Remove old furniture thrown in rear of complex.
4.10	Other Rooms/Smoke Detectors Smoke detector is missing. All units must have at least one operable smoke detector in each bedroom and in a common area on each level.
4.6	Other Rooms/Celing Condition 1. Address discoloration on ceiling 2. Repair cracks on walls and ceiling, cockroach infested and coming out of walls
3.8	Bathroom/Floor Condition Repair/replace damaged flooring
8.6	General Health and Safety/Interior Stairs and Common Halls Replace missing common area smoke detector/ carbon monoxide detector
2.10	Kitchen/Stove or Range with Oven Range hood microwave damaged, repair, remove or replace



9/14/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2595 LANCASTER DR Apt Unit 12
RICHMOND, CA 94806-

PropID:
Client ID: 12750

Dear Current Resident,

This letter is to inform you that your property at **2595 LANCASTER DR Apt Unit 12 RICHMOND, CA 94806** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 10/21/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS</u>
8.1	General Health and Safety/Access to Unit Site security gates are not operating, repair as doors must be locked or have the ability to be locked
2.12	Kitchen/Sink Garbage disposal has evidence of leak and gunky material on exterior, repair or replace
8.3	General Health and Safety/Evidence of Infestation Exterminate for roaches.
2.13	Kitchen/Space for Storage, Prep and Serving Replace missing kitchen drawer fronts
8.10	General Health and Safety/Site and Neighborhood Conditions Laundry room missing smoke detector, replace



9/14/2026

FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 8
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 8 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/16/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
4.10	Other Rooms/Smoke Detectors Smoke detector is missing. All units must have at least one operable smoke detector in each bedroom and in a common area on each level.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 15
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 15 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/16/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
7.1	Heating and Plumbing/Adequacy of Heating Equipment Living room heater control knob missing, replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 22
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 22 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/16/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.5	Kitchen/Window Condition Lower fixed window rusted, repair or replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2385 LANCASTER DR Apt 24
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2385 LANCASTER DR Apt 24 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/16/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.5	Kitchen/Window Condition Lower fixed window rusted, repair or replace
3.12	Bathroom/Tub or Shower Shower head leaking in rear

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2409 LANCASTER DR Apt 21
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2409 LANCASTER DR Apt 21 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2409 LANCASTER DR Apt 24
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2409 LANCASTER DR Apt 24 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12 Kitchen/Sink	Dishwasher inoperable as control knob is missing, replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2425 LANCASTER DR Apt 2
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2425 LANCASTER DR Apt 2 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.5	Kitchen/Window Condition dining area window frame rusted - repair/remove/replace
7.1	Heating and Plumbing/Adequacy of Heating Equipment living room wall heater inop

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2425 LANCASTER DR Apt 11
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2425 LANCASTER DR Apt 11 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12	Kitchen/Sink dishwasher not working/draining properly - repair/replace
2.3	Kitchen/Electrical Hazards GFCI outlet missing

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2425 LANCASTER DR Apt 13
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2425 LANCASTER DR Apt 13 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2425 LANCASTER DR Apt 19
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2425 LANCASTER DR Apt 19 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2425 LANCASTER DR Apt 20
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2425 LANCASTER DR Apt 20 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
3.11	Bathroom/Fixed Wash Basin or Lavatory in Unit Rust in sink, reglaze sink or replace
4.10	Other Rooms/Smoke Detectors Replace, exceeds 10 year life span
4.4	Other Rooms/Security Remove keyed lock from interior door.

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2445 LANCASTER DR Apt 1
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2445 LANCASTER DR Apt 1 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
3.11	Bathroom/Fixed Wash Basin or Lavatory in Unit sink has corrosion - resurface/replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2445 LANCASTER DR Apt 2
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2445 LANCASTER DR Apt 2 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12	Kitchen/Sink

dishwasher not closing properly and rusted inside - repair/replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2445 LANCASTER DR Apt 10
RICHMOND, CA 94806-2590-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2445 LANCASTER DR Apt 10 RICHMOND, CA 94806-2590** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
4.10	Other Rooms/Smoke Detectors bedroom smoke detector missing

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2420 LANCASTER DR Apt 7
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2420 LANCASTER DR Apt 7 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2420 LANCASTER DR Apt 9
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2420 LANCASTER DR Apt 9 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 09:00AM and 12:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12	Kitchen/Sink dishwasher not working/draining properly - repair/replace

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2400 LANCASTER DR Apt 3
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2400 LANCASTER DR Apt 3 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/16/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
4.4	Other Rooms/Security bedroom door of hinges - repair

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2400 LANCASTER DR Apt 4
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2400 LANCASTER DR Apt 4 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/16/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
3.10	Bathroom/Flush Toilet in Enclosed Room in Unit toilet base loose

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2400 LANCASTER DR Apt 5
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2400 LANCASTER DR Apt 5 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/16/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2400 LANCASTER DR Apt 7
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2400 LANCASTER DR Apt 7 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/16/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2410 LANCASTER DR Apt 12
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2410 LANCASTER DR Apt 12 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/16/2026 between 01:00PM and 04:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
2.12 Kitchen/Sink	dishwasher not working/draining properly - repair/replace
3.10 Bathroom/Flush Toilet in Enclosed Room in Unit	toilet base loose
7.1 Heating and Plumbing/Adequacy of Heating Equipment	heater fan very loud

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2420 LANCASTER DR Apt 4
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2420 LANCASTER DR Apt 4 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

<u>Area</u>	<u>REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS</u>
8.7	General Health and Safety/Other Interior Hazards hallway smoke detector missing

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program



9/14/2026

FAILED INSPECTION NOTICE

2430 LANCASTER DR Apt 11
RICHMOND, CA 94806-3087-

PropID:
Client ID: 6239

Dear Current Resident,

This letter is to inform you that your property at **2430 LANCASTER DR Apt 11 RICHMOND, CA 94806-3087** failed the Housing Quality Standards (HQS) inspection on 09/10/2026.

A re-inspection has been scheduled for 11/17/2026 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an “O” are the responsibility of the Owner and the items marked with a “T” are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR “FAIL” RATING AND OTHER COMMENTS

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,

City of Richmond
Residential Rental Inspections Program