

FAILED INSPECTION NOTICE

Roberto & Esperanza Ramos 1408 Bush Ave San Pablo, CA 94804-1524 Property: 632 18TH ST Apt 1 RICHMOND, CA 94801-2816-

PropID:

Client ID: 16684

Dear Owner/Agent,

This letter is to inform you that your property at 632 18TH ST Apt 1 RICHMOND, CA 94801-2816 failed the Housing Quality Standards (HQS) inspection on 10/23/2023.

A re-inspection has been scheduled for 11/28/2023 between 11:00AM and 02:00PM.



FAILED INSPECTION NOTICE

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
7.1	Heating and Plumbing/Adequacy of Heating Equipment	O
	heater turned off by Pg&e for safety reasons	
8.7	General Health and Safety/Other Interior Hazards	O
	1. check electrical in unit per pg&e	
4.4	Other Rooms/Security	O
	remove deadbolt lock from door, safety hazard	
4.7	Other Rooms/Wall Condition	O
	remove black discoloration	
4.5	Other Rooms/Window Condition	O
	bedroom window will not stay up as designed, repair/replace	
4.8	Other Rooms/Floor Condition	O
	floor deteriorating, replace	
2.6	Kitchen/Ceiling Condition	O
	ceiling has evidence of water damage, repair	
2.3	Kitchen/Electrical Hazards	O
	light switch next to microwave not working as designed, repair	
2.12	Kitchen/Sink	O
	faucet loose,repair/replace	
2.13	Kitchen/Space for Storage, Prep and Serving	O
	cabinet doors of hinges,repair/replace	
3.7	Bathroom/Wall Condition	O
	remove excessive black discoloration	
3.6	Bathroom/Ceiling Condition	O
	remove excessive black discoloration	
3.12	Bathroom/Tub or Shower	O
	1.tub sinking down and rusting, resurface/replace/repair tub	
	2. tub diverter not working as designed, repair/replace	
3.4	Bathroom/Security	O
	door frame damaged ,repair/replace	
6.4	Building Exterior/Condition of Exterior Surfaces	O
	exterior window frames peeling paint,repair	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Leslie F & Sheila Claudio LEONARD CLAUDIO 3875 Fairfax Rd Prescott Valley, AZ 86314 Property: 441 A ST RICHMOND, CA 94801-2916-

PropID:

Client ID: 3537

Dear Owner/Agent,

This letter is to inform you that your property at **441 A ST RICHMOND**, **CA 94801-2916 failed** the Housing Quality Standards (HQS) inspection on 10/23/2023.

A re-inspection has been scheduled for 11/28/2023 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS 8.7 General Health and Safety/Other Interior Hazards unable to perform inspection, no PG&E service,

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Harbor Apts Llc Palm
Project Solutions Llc
3630 Telegraph Ave
Oakland, CA 94609

203 16TH ST Apt 1

RICHMOND, CA 94801-3248-

PropID:

Property:

Client ID: 16804

Dear Owner/Agent,

This letter is to inform you that your property at **203 16TH ST Apt 1 RICHMOND, CA 94801-3248 failed** the Housing Quality Standards (HQS) inspection on 10/23/2023.

A re-inspection has been scheduled for 11/28/2023 between 01:00PM and 04:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
3.7	Bathroom/Wall Condition	O
	1. excessive black discoloration,repair	
	2. towel bar missing,repair	
6.2	Building Exterior/Condition of Stairs, Rails, and Porches	O
	front exterior staircase missing handrails, install, safety hazard	
8.7	General Health and Safety/Other Interior Hazards	O
	1. excessive clutter in unit, clean/organize unit. safety hazard (tenant)	
	2. install co detector	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Hui Xian Situ 50 Beverly St San Francisco, CA 94132 2225 MACDONALD Apt LOWER RICHMOND, CA 94801-3312-

PropID:

Property:

Client ID: 19138

Dear Owner/Agent,

This letter is to inform you that your property at 2225 MACDONALD Apt LOWER RICHMOND, CA 94801-3312 failed the Housing Quality Standards (HQS) inspection on 10/23/2023.

A re-inspection has been scheduled for 11/28/2023 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
7.4	Heating and Plumbing/Water Heater	O
	1. Earthquake straps needed on top and bottom.	
	2. The water heater must be equipped with both a temperature-pressure	
	relief valve and discharge line to run outside	
8.7	General Health and Safety/Other Interior Hazards	O
	1. install common area smoke detectors	

2. install common area co detectors



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Hui Xian Situ 50 Beverly St San Francisco, CA 94132 2227 MACDONALD Apt UPPER RICHMOND, CA 94801-3312-

PropID:

Property:

Client ID: 19138

Dear Owner/Agent,

This letter is to inform you that your property at **2227 MACDONALD Apt UPPER RICHMOND, CA 94801-3312 failed** the Housing Quality Standards (HQS) inspection on 10/23/2023.

A re-inspection has been scheduled for 11/28/2023 between 11:00AM and 02:00PM.

It is your responsibility to correct the following items as shown below. The Items marked with an "O" are the responsibility of the Owner and the items marked with a "T" are the responsibility of the Tenant. Please inform your tenant of any tenant responsible fail items.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
7.4	Heating and Plumbing/Water Heater	O
	The water heater must be equipped with both a temperature-pressure relief	
	valve and discharge line to run outside	
8.7	General Health and Safety/Other Interior Hazards	O
	install co detectors in common areas	

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Fred & Carol Lum Li 912 Via Del Paz Livermore, CA 94550 Property: 775 HUMBOLDT ST Apt A RICHMOND, CA 94805-1440-

PropID:

Client ID: 7764

Dear Owner/Agent,

This letter is to inform you that your property at 775 HUMBOLDT ST Apt A RICHMOND, CA 94805-1440 failed the Housing Quality Standards (HQS) inspection on 10/23/2023.

A re-inspection has been scheduled for 11/28/2023 between 09:00AM and 12:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
3.12	Bathroom/Tub or Shower	O
	shower enclosure has black discoloration, repair/remove	
2.12	Kitchen/Sink	O
	1. recaulk around sink	
	2. evidence of leaking, repair	
2.11	Kitchen/Refrigerator	O
	light out, repair	
2.13	Kitchen/Space for Storage, Prep and Serving	O
	top of cabinet left of sink, evidence of water damage/ previous leak, repair	
4.10	Other Rooms/Smoke Detectors	O
	Smoke detector is missing/inoperable. All units must have at least one	
	operable smoke detector in each bedroom and in a common area on each	
	level.	
7.4	Heating and Plumbing/Water Heater	O
	check water heater, kitchen hot water has black particles coming out in	
	water,repair	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Xuan Phi Chi
5350 Brookwood Ct
Richmond, CA 94803

Property: 875 HUMBOLDT ST Apt REAR UPPER RICHMOND, CA 94805-1442-

PropID:

Client ID: 17312

Dear Owner/Agent,

This letter is to inform you that your property at **875 HUMBOLDT ST Apt REAR UPPER RICHMOND**, **CA 94805-1442 failed** the Housing Quality Standards (HQS) inspection on 10/23/2023.

A re-inspection has been scheduled for 11/28/2023 between 09:00AM and 12:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
3.7	Bathroom/Wall Condition	O
	vanity mirror deteriorating/water damaged, replace	
3.5	Bathroom/Window Condition	O
	evidence of water damage/deteriorating, repair	
3.3	Bathroom/Electrical Hazards	O
	light fixture has excessive rusting/deterioration, replace	
4.3	Other Rooms/Elecrtical Hazards	O
	light fixture inoperable, repair	
1.4	Living Room/Security	O
	Front door deteriorating/rusting health and safety hazard, repair/replace	
1.5	Living Room/Window Condition	O
	window has black discoloration, repair	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Will Dot Apartments Llc Jeannette Maynard Po Box 775 Shingle Springs, CA 95682-0775 Property: 5226 SOLANO AVE Apt D RICHMOND, CA 94805-1463-

PropID:

Client ID: 14654

Dear Owner/Agent,

This letter is to inform you that your property at **5226 SOLANO AVE Apt D RICHMOND, CA 94805-1463 failed** the Housing Quality Standards (HQS) inspection on 10/23/2023.

A re-inspection has been scheduled for 11/28/2023 between 09:00AM and 12:00PM.

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
4.10	Other Rooms/Smoke Detectors	O
	Smoke detector is missing/inoperable. All units must have at least one	
	operable smoke detector in each bedroom and in a common area on each	
	level.	
7.4	Heating and Plumbing/Water Heater	O
	unable to inspect water heate	
1.8	Living Room/Floor Condition	O
	carpet in livingroom/hallway is deteriorating, worn/soiled/ripped,	
	repair/replace carpet	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,



FAILED INSPECTION NOTICE

Miguel A & Angelina A Cardona 734 Hampshire St San Francisco, CA 94110-2130 Property: 428 34TH ST RICHMOND, CA 94805-2117-

PropID:

Client ID: 6852

Dear Owner/Agent,

This letter is to inform you that your property at **428 34TH ST RICHMOND**, **CA 94805-2117 failed** the Housing Quality Standards (HQS) inspection on 10/23/2023.

A re-inspection has been scheduled for 11/28/2023 between 09:00AM and 12:00PM.



FAILED INSPECTION NOTICE

Area	REASON(S) FOR "FAIL" RATING AND OTHER COMMENTS	Tenant/Owner
2.3	Kitchen/Electrical Hazards	O
	install Gfi outlets	
2.12	Kitchen/Sink	O
	recaulk behind sink	
2.11	Kitchen/Refrigerator	O
	light inside refrigerator inop,repair	
1.3	Living Room/Electrical Hazards	О
	outlets not wired correctly, repair Three prong outlet not testing as	
	designed, must be grounded, replaced with a two-prong outlet or replaced	
	with a GFCI.	
3.12	Bathroom/Tub or Shower	O
	resurface tub	
3.3	Bathroom/Electrical Hazards	O
	install Gfi outlet	
3.11	Bathroom/Fixed Wash Basin or Lavatory in Unit	O
	repair wall under sink evidence of water damage	
5.3	Secondary Rooms/Electrical Hazards	O
	install Gfi outlet next to water source	
7.4	Heating and Plumbing/Water Heater	O
	The water heater must be equipped with both a temperature-pressure relief	
	valve and discharge line down to run outside	
7.1	Heating and Plumbing/Adequacy of Heating Equipment	O
	heater inoperable ,repair	
8.10	General Health and Safety/Site and Neighborhood Conditions	O
	cut overgrown vegetation,backyard	



FAILED INSPECTION NOTICE

Please be advised that if the **Owner** does not complete the repairs that are his/her responsibility, additional fees may apply.

Please be advised that if the Tenant does not complete the repairs that are his/her responsibility and the owner cannot provide proper proof of notification to the tenant regarding the items, the owner becomes responsible for ensuring the repairs are completed.

If you have any questions regarding your inspection or any fail items, please contact us by phone at 510-690-8260 for further information.

Sincerely,